



NOTES:

CONDUITS, SIZE, QUANTITY AND LOCATIONS PER PROJECT PLANS AND AS REQUIRED FOR A COMPLETE INSTALLATION.

SPECIAL NOTES:

- ① TRANSFORMER PAD. DIMENSIONS OF PAD SHALL EXCEED TRANSFORMER BASE DIMENSIONS.
- ② PROVIDE EXOTHERMIC WELDS FOR BURIED CONNECTIONS AND MECHANICAL BOLTED CONNECTIONS FOR ACCESSIBLE CONNECTIONS.
- ③ COVERED ACCESS OPENING, MARKED "DANGER-HIGH VOLTAGE" ON WARNING PLATE.
- ④ SLAB BOX 4'-0" X 7'-0" INTERIOR DIMENSIONS.
- ⑤ INSTALL FIBERGLASS UNISTRUT CHANNEL TO SUPPORT CABLE AT PAD OPENING.
- ⑥ AFTER TRANSFORMER IS SECURED AND ANCHORED, INSTALL A BEAD OF CLEAR SEALANT (MINIMUM 1/4" THICK) TO CLOSE ALL GAPS BETWEEN THE TRANSFORMER ENCLOSURE AND FRAME AND PAD.
- ⑦ CONTRACTOR PROVIDED AND INSTALLED TRANSFORMER ENGRAVED IDENTIFICATION LABEL.
- ⑧ CONTRACTOR PROVIDED AND INSTALLED ARC FLASH HAZARD WARNING LABEL.
- ⑨ CONTRACTOR PROVIDED AND INSTALLED "DANGER-HIGH VOLTAGE" WEATHERPROOF WARNING LABEL.