

Fire Protection Inspection, Testing, and Maintenance Requirements

01/01/2021

Effective Date

Table of Contents

1. SCOPE	1
2. DISCUSSION	1
3. DEFINITIONS	2
4. RESPONSIBILITIES	3
5. INSTRUCTIONS	3
6. RECORDS.....	11
7. REFERENCES	11
8. DOCUMENT OWNERSHIP AND MAINTENANCE	12

ATTACHMENTS:

Attachment 1: Standardized SFM AES Inspection Testing and Maintenance Forms

1. SCOPE

This procedure provides an overview of requirements for inspections, maintenance, and testing of fire protection systems and features at Cal Poly. Requirements are summarized for each category of equipment as well as any qualification requirements of personnel who perform the work.

2. DISCUSSION

- 2.1. The Office of the State Fire Marshal (SFM) is the authority having jurisdiction responsible for enforcing the requirements of applicable fire protection regulations, codes, and standards. The SFM is also the authority for approving equipment, materials, installation, or a procedure that is credited to comply with applicable requirements.
- 2.2. Regulations, codes, and standards applicable to fire protection systems and features at Cal Poly specify preventative maintenance requirements to ensure equipment reliability.
- 2.3. Fire protection systems and features have unique design and installation requirements that may not be familiar to personnel performing work on this equipment. Because

maintaining fire protection systems and features is critical for life safety and protection of property, minimum qualifications or certifications are required for performing work on some systems and features.

- 2.4. This procedure does not provide a comprehensive set of maintenance requirements. This procedure will reference regulations, codes, or standards for additional details on requirements where appropriate.

3. DEFINITIONS

- 3.1. Authority Having Jurisdiction (AHJ): An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure. For state owned or operated buildings, the AHJ is the State Fire Marshal.
- 3.2. Automatic Fire Extinguishing System (AES): Includes, but is not limited to, fire sprinkler systems, engineered and pre-engineered fixed extinguishing systems, standpipe systems, and alarm and supervisory equipment attached to those systems (CA HSC §13195).
- 3.3. Battery-Powered Lighting Units: Individual unit equipment for backup illumination consisting of a rechargeable battery, battery-charging means, provisions for one or more lamps mounted on the equipment, or with terminals for remote lamps, or both, and relaying device arranged to energize the lamps automatically upon failure of the supply to the unit equipment.
- 3.4. Emergency Lighting: Lighting units that provide illumination of rooms and egress routes upon loss of normal power supplies to the building
- 3.5. Fire Alarm Control System (FACS): A system or portion of a combination system consisting of components and circuits arranged to monitor and annunciate the status of fire alarm or supervisory signal-initiating devices and to initiate the appropriate response to those signals.
- 3.6. Fire Rated Assembly: Includes materials, systems and assemblies used for structural fire resistance, fire-resistance- rated construction separation of adjacent spaces and construction installed to resist the passage of smoke to safeguard against the spread of fire and smoke within a building and the spread of fire to or from buildings (2019 CFC 701.1);
- 3.7. Portable fire extinguisher: Devices that are carried or on wheels and operated by hand, containing an extinguishing agent that can be expelled under pressure for the purpose of suppressing or extinguishing fire. Typical extinguishing agents and associated performance standards include (NFPA 10 2018):
- Dry chemical (ANSI/UL 299)
 - Water type (ANSI/UL 626)
 - Carbon Dioxide (ANSI/UL 154)
 - Halon type (CAN/ULC-S512)

- Film-forming foam type (ANSI/UL 8)
 - Halocarbon type (ANSI/UL 2129)
- 3.8. State Fire Marshal (SFM): The State Fire Marshal administers the Office of the State Fire Marshal. The functions of the office are to foster, promote and develop ways and means of protecting life and property against fire and panic. The State Fire Marshal is appointed by the Governor with the advice and consent of the Senate (CA HSC §13100).
- 3.9. Standpipe: The system piping that delivers the water supply for hose connections, and for sprinklers on combined systems, vertically from floor to floor.

4. RESPONSIBILITIES

- 4.1. EHS Program Owner
- 4.1.1. Identifying inspection, maintenance and testing requirements for fire protection systems and features
 - 4.1.2. Maintaining this procedure
- 4.2. Facility Operations
- 4.2.1. Creation of Preventative Maintenance Plans
 - 4.2.2. Performing or delegating maintenance activities to ensure fire protection systems and features receive required inspection, maintenance, and testing.
- 4.3. Contractors
- 4.3.1. Contractors performing work within the scope of this procedure shall follow the requirements of this procedure or equivalent.

5. INSTRUCTIONS

- 5.1. General
- 5.1.1. Inspection, testing, and maintenance personnel shall at a minimum be under the supervision of a responsible person who shall ensure that such maintenance and testing are conducted at specified intervals (2019 CFC §108.4). Additional personnel qualifications may be required as specified.
 - 5.1.2. Personnel who perform inspections, testing, or maintenance required by this procedure are required to document each inspection using the appropriate form included in this procedure. Records shall be provided to EH&S where they will be maintained for the required duration specified in Section 6.
- 5.2. Fire Protection Water Supplies and Hydrants
- 5.2.1. Fire Hydrant Systems Inspection, Testing, and Maintenance Requirements
 - a. Private fire hydrants of all types: Inspection annually and after each operation; flow test and maintenance annually

- b. Fire service main piping: Inspection of exposed, annually; flow test every 5 years.
- c. Fire service main piping strainers: Inspection and maintenance after each use.
- d. Records of inspections, testing and maintenance shall be maintained.

5.3. Automatic Fire Extinguishing Systems (AES)

5.3.1. AES Installation, Maintenance, and Testing Personnel

- e. As depicted in Figure 1 below, the California Health and Safety Code requires that personnel who install, alter, repair, or add appurtenances to AES systems shall maintain an active certification issued by the Office of the State Fire Marshal.




Figure 1 – Automatic Fire Extinguishing System Personnel Requirements

f. AES Sprinkler Fitter Trainee and Apprenticeship Program

1. The Fire Sprinkler Fitter Trainee and Apprenticeship Program must be completed prior to applying for a Sprinkler Fitter Certification.
2. Trainees and Apprentices must also be registered with the Office of the State Fire Marshal utilizing application form AES 1005A and shall work under the direct supervision of a Certified Fire Sprinkler Fitter at all times (19 CCR § 937-938).

g. AES Sprinkler Fitter Certification

Any person who installs, alters, repairs, or adds appurtenances to water-based fire protection systems shall be currently registered and certified in accordance with the Office of the State Fire Marshal utilizing application form AES 1005 (19 CCR § 939).

5.3.2. AES Inspection, Testing, and Maintenance Requirements

- a. Water-based fire protection systems shall be inspected, tested and maintained in accordance with the frequencies required by NFPA 25 (2011 edition) including Annexes A, B, C, D, F and G as amended by the State of

California (Published as NFPA 25, 2013 California Edition) (2019 CFC §904(a)(1).

- b. Engineered and pre-engineered fixed extinguishing systems shall be inspected, tested and maintained at least semi-annually, and immediately after a system activation (2019 CFC §904(a)(2).
- c. The forms referenced in Table 1 were developed by the Office of the State Fire Marshal and shall be used to record the results of all inspections, testing, and maintenance of water-based fire protection systems. The completed forms shall be provided to the authority having jurisdiction as indicated (2019 CFC §906.4(a)). All standardized forms are dated 9-3-2013.

Table 1 – Standardized SFM AES Inspection Testing and Maintenance Forms

Form Number	Description	Frequency	Retained On-Site	Forward to AHJ
AES 1	Inspection, Testing, and Maintenance Cover Sheet		X	X
<i>Sprinkler Systems</i>				
AES 2.1	Wet Pipe Fire Sprinkler System	Quarterly/ Annual	X	
AES 2.2	Wet Pipe Fire Sprinkler System	Five Year	X	X
AES 2.3	Dry Pipe Fire Sprinkler System	Quarterly/ Annual	X	
AES 2.4	Dry Pipe Fire Sprinkler System	Five Year	X	X
AES 2.5	Pre-action Sprinkler Systems	Quarterly/ Annual	X	
AES 2.6	Pre-action Sprinkler Systems Water	Five Year	X	X
AES 2.7	Deluge Sprinkler Systems Water Spray	Quarterly/ Annual	X	
AES 2.8	Deluge Sprinkler Systems Water Spray	Five Year	X	X
AES 2.9	Main Drain Test Continuation Form ¥		¥	¥
AES 3	Standpipe and Hose System	Quarterly/ Annual	X	
AES 3.1	Standpipe and Hose System	Five Year	X	X
AES 4	Private Fire Service Main	Quarterly/ Annual	X	
AES 4.1	Private Fire Service Main	Five Year	X	X
<i>Fire Pumps</i>				
AES 5.1	Diesel Fire Pump	Weekly	X	
AES 5.2	Diesel Fire Pump	Annual	X	
AES 5.3	Electric Fire Pump	Monthly	X	X
AES 5.4	Electric Fire Pump	Annual	X	X
<i>Other Forms</i>				
AES 6	Water Storage Tanks	Annual	X	X
AES 7	Water Spray Fixed System		X	X
AES 8	Foam-Water Sprinkler System		X	X

AES 9	Continuation Form for Deficiencies and Comments ☹		☹	☹
AES 10	Corrective Action and Repairs Performed ☹		☹	☹
<i>Engineered and Pre-Engineered Systems</i>				
AES 20	Wet Chemical Pre-Engineered Fire Extinguishing System	Semi-Annual	X	X
AES 21	Dry Chemical Pre-Engineered Fire Extinguishing System	Semi-Annual	X	X
AES 22	Specialty Pre-Engineered and Engineered Fire Extinguishing System	Semi-Annual	X	X

Table 1 Notes

- 1 AES-1 shall be attached and maintained as applicable to AES Forms 2 through 8.
- 2 AES-9 (when attached) shall be maintained as applicable to AES forms 2 through 8.
- 3 The local Fire Code or Building Code official may require additional AES forms to be submitted based on protected hazard and/or complexity.
- 4 Any critical deficiency of a fire protection system shall result in the appropriate AES form being sent to the Fire Code or Building Code official ☹ Form will only be sent to AHJ if needed.
- ☹ Form will only be sent to AHJ if needed.

5.4. Standpipes and Hose Systems

5.4.1. Standpipe and Hose Systems Scope

A standpipe and hose system is an arrangement of piping, valves, hose connections, an associated equipment installed in a building or structure, with the hose connections located in such a manner that water can be discharged in streams or spray patters through attached hose and nozzles, for the purpose of extinguishing a fire (NFPA 14 2019).

5.4.2. Standpipe and Hose Systems Installation, Maintenance, and Testing Personnel

If a standpipe provides firewater supply to automatic fire extinguishing equipment, ensure personnel qualifications outlined in Section 5.3.1 are satisfied prior to any installation, alteration, or repair.

Maintenance and testing shall be under the supervision of a responsible person who shall ensure that such maintenance and testing are conducted at specified intervals (2019 CFC §108.4).

5.4.3. Standpipe and Hose Systems Maintenance and Testing Requirements

Refer to applicable requirements of Section 5.3.2 of this procedure.

5.5. Fire Alarm Control Systems (FACS)

5.5.1. Fire Alarm Control System Inspection Testing and Service Personnel

- a. As outlined in Figure 2, service personnel shall meet the qualification requirements of NFPA 72 for inspection, testing and maintenance of fire alarm control systems (2019 CFC § 907.8.5).




Figure 2 - Fire Alarm Control System Personnel Requirements

- b. Inspection, Testing and service personnel who perform work on fire alarm control systems shall have the knowledge and experience of the work they are performing that's acceptable to the authority having jurisdiction or shall be, but not limited to, one or more of the following (NFPA 72-2019, Section 10.5.3):
 1. Factory trained and certified for the specific type and brand of system being serviced
 1. Certified by a nationally recognized certification organization acceptable to the authority having jurisdiction
 2. Registered, licensed, or certified by a state or local authority to perform service on systems addressed within the scope of NFPA 72, either individually or through their affiliation with an organization.
 3. Employed and qualified by an organization listed by a nationally recognized testing laboratory for the servicing of systems within the scope of NFPA 72.

5.5.2. FACS Maintenance and Testing Requirements

- a. Testing shall be performed in accordance with the maintenance schedules in NFPA 72.
- b. Smoke detector sensitivity. Smoke detector sensitivity shall be checked within one year after installation and every alternate year thereafter. After the second calibration test, where sensitivity tests indicate that the detector has remained within its listed and marked sensitivity range (or 4-percent obscuration light gray smoke, if not marked), the length of time between calibration tests shall be permitted to be extended to not more than 5 years. Where the frequency is extended, records of detector- caused nuisance alarms and subsequent trends of these alarms shall be maintained. In zones or areas where nuisance alarms show any increase over the previous year, calibration tests shall be performed (2019 CFC §907.8.3).

5.6. Smoke Control Systems

- 5.6.1. Where a fire alarm system is integrated with a smoke control system, integrated testing shall be performed per NFPA 4 at intervals not exceeding 10 years unless otherwise specified by an integrated system test plan prepared in accordance with NFPA 4 (2019 CFC . 901.6.2.2).
- 5.6.2. Inspection, testing, and maintenance of smoke and heat vents shall be in accordance with NFPA 204 except as follows (2019 CFC §910.5):
 - a. Mechanically operated smoke and heat vents shall be inspected annually and operationally tested not less than every 5 years.
 - b. Gravity dropout smoke and heat vents shall be inspected annually.
 - c. Fused, damaged or painted fusible links shall be replaced.

5.7. Portable Fire Extinguishers

5.7.1. Portable Fire Extinguisher Installation, Maintenance, and Testing Personnel



Figure 3 – Portable Fire Extinguisher Personnel Requirements

- a. No person shall engage in the servicing and maintenance of portable fire extinguishers without having first submitted an application and all documents, necessary to demonstrate compliance with and having obtained a license from the State Fire Marshal. (19 CCR §560).
- b. A prospective licensee must provide written proof of their service experience in order to be licensed. The prospective licensee shall provide written documentation that they have at least 24 months of experience with portable fire extinguishers in all the following areas:

- Servicing,
- Maintenance,
- Recharging,
- Repairing,
- Hydrostatic testing and
- Installation.

This shall be accomplished by having their fire extinguisher service employer submit letter (s) on their letter head attesting to this experience. This correspondence shall indicate their length of employment, an estimate of the number and type of portable fire extinguishers that they have experience with and a statement that the individual has the necessary experience to obtain a license. Additional documentation may include training certificates from the various fire extinguisher manufacturers and college classes related to Fire Science.

EXCEPTION: An applicant for a Limited License does not need to meet the 24 month of experience but shall submit their work experience and lesson plan/work instructions for performing an annual external maintenance in lieu of the 24 month requirement (19 CCR §595.5(f)).

5.7.2. Portable Fire Extinguisher Inspection, Maintenance and Testing Requirements

- a. Fire extinguishers shall be manually inspected when initially placed in service. Thereafter extinguishers shall be manually inspected at least monthly. Fire extinguishers shall be inspected at more frequent intervals when circumstances require as determined by the Authority Having Jurisdiction. Manual inspection shall include a check of at least the following items: (19 CCR §574.1-2)
 1. Located in designated place.
 2. No obstruction to access or visibility.
 3. Operating instructions on nameplate legible and facing outward.
 4. Safety seals and tamper indicators not broken or missing.
 5. Examine for obvious physical damage, corrosion, leakage or clogged nozzle.
 6. Pressure gauge reading or indicator in the operable range or position.
 7. Fullness determined by weighing or hefting.
 8. For wheeled units, the condition of tires, wheels, carriage, hose, and nozzle shall also be checked.
 9. For non-rechargeable extinguishers using push-to-test pressure indicators, test the indicator.
- b. When an inspection of any extinguisher reveals a deficiency in any of the conditions listed in 5.7.2a, immediate corrective action shall be taken (19 CCR §574.3). Refer to 19 CCR Table 4 for appropriate corrective actions to address various deficiencies.

- c. Records of all fire extinguishers inspected shall be maintained, including those extinguishers that were found to require corrective actions. Records shall be maintained until next required maintenance. At least monthly, the date the manual inspection was performed and the initials of the person performing the inspection shall be recorded on a tag or label attached to the fire extinguisher, or an inspection checklist maintained on file, or an electronic system (e.g. bar coding) that provides a permanent record (19 CCR §574.5).
- d. Fire extinguishers shall be subjected to maintenance annually by a fire extinguisher license holder as decreed in Section 5.7.1 of this procedure. Annual servicing shall be performed as described in 19 CCR § 575 or immediately after use or when specifically indicated by an inspection or at the time of hydrostatic test. For purposes of maintenance, hydrostatic tests required during the same calendar year shall be performed at the time of the annual maintenance or recharge.
- e. Non-rechargeable fire extinguishers shall not be recharged or hydrostatically tested but shall be discharged and removed from service at a maximum interval of 12 years from the date of manufacture (19 CCR § 575.1).

5.8. Emergency Lighting

5.8.1. Inspections and Testing Requirements

- a. Monthly activation test. Emergency lighting equipment shall be tested monthly for a duration of not less than 30 seconds. The test shall be performed manually or by an automated self-testing and self-diagnostic routine. Where testing is performed by self-testing and self-diagnostics, a visual inspection of the emergency lighting equipment shall be conducted monthly to identify any equipment displaying a trouble indicator or that has become damaged or otherwise impaired (2019 CFC §1031.10.1).
- b. Annual power test. Battery-powered emergency lighting equipment shall be tested annually by operating the equipment on battery power for not less than 90 minutes (2019 CFC §1031.10.2).

5.9. Fire Rated Assemblies

5.9.1. Maintenance and testing personnel shall be under the supervision of a responsible person who shall ensure that such maintenance and testing are conducted at specified intervals (2019 CFC §108.4).

5.9.2. Fire Rated Assemblies Maintenance and Testing

- a. Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening

- protectives and smoke and draft control doors shall not be modified (2019 CFC §705.2).
- b. Hold-open devices and automatic door closers, where provided, shall be maintained. Swinging fire doors shall close from the full-open position and latch automatically. During the period that such device is out of service for repairs, the door it operates shall remain in the closed position (2019 CFC §705.2.3-4).
- c. Horizontal and vertical sliding and rolling fire doors shall be inspected and tested annually to confirm proper operation and full closure. Records of inspections and testing shall be maintained (2019 CFC §705.2.6).
- d. Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105 (2019 CFC §706.1).

6. RECORDS

- 6.1. A record of periodic inspections, tests, servicing and other operations and maintenance shall be maintained by EH&S on campus or other approved location for not less than 3 years, or as specified in the Table 2 below (2019 CFC §108.3).
- 6.2. Records shall be made available for inspection by the fire code official, and a copy of the records shall be provided to the fire code official on request (2019 CFC §108.3).

Table 2 – Record Retention Schedule for Fire Protection Inspections, Testing, and Maintenance

Record ID	Description	Retention Period	Reference
Hydrant Systems	Fire Hydrants, mains, and water tanks	3 years	2019 California Fire Code
AES	Automatic fire extinguishing system inspections, tests, and maintenance activities.	5 years after the next required inspection	19 CCR Division 1 §904.1(b), §904.2(c)
Fire Extinguisher			

7. REFERENCES

- 7.1. California Health and Safety Code, Division 12, Fires and Fire Protection
- 7.2. 24 CCR Part 9, California Fire Code
- 7.3. 19 CCR Division 1, State Fire Marshal
- 7.4. NFPA 10, Standard for Portable Fire Extinguishers
- 7.5. NFPA 14, Standard for the Installation of Standpipe and Hose Systems
- 7.6. NFPA 25 2013 California Edition, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems
- 7.7. NFPA 72, National Fire Alarm and Signaling Code

- 7.8. NFPA 80, Standard for Fire Doors and Other Opening Protectives
- 7.9. NFPA 105, Standard for Smoke Door Assemblies and Other Opening Protectives

8. DOCUMENT OWNERSHIP AND MAINTENANCE

- 8.1. Document Owner
Environmental Health and Safety
- 8.2. Document Approvals
Director, Environment Health & Safety
- 8.3. Revision History
 - 8.3.1. Revision 0: Initial issuance.

Inspection, Testing, and Maintenance Cover Sheet NFPA25 as amended by CCR, Title 19

Property Information:

Name: _____	Occupancy/Use: _____
Address: _____	Construction Type: _____
City: _____	No. Stories: _____
ZIP: _____	Year Constructed: _____
Contact: _____	
Telephone: _____	



Contractor Information:

Number of System Risers

Name: _____

Address: _____

City: _____

State: _____

Telephone: _____

CA License#: _____

Job #: _____

Performed by: _____

Copy sent to:

<input type="checkbox"/> Owner	Date: _____
<input type="checkbox"/> Fire AHJ	Date: _____
<input type="checkbox"/> Contractor	Date: _____

NOTES:

- 1) For specific inspection, testing, and maintenance requirements and information, see NFPA 25, 2011 edition as amended by California Code of Regulations, Title 19, §901 to §906.
- 2) Inspection items may be performed by the owner in accordance with California Code of Regulations, Title 19, §904.1(a)

**Check box for each system inspected and enter the number of forms used for inspection.
Check boxes (Fail or Pass) to indicate status of inspected system at end of inspection.**

Forms Included with this Report	NFPA 25 Chapter	Number of Forms	N/A	Fail*	Pass
<input type="checkbox"/> Automatic Sprinkler System	5				
<input type="checkbox"/> Standpipe and Hose System	6				
<input type="checkbox"/> Private Water Supply System	7				
<input type="checkbox"/> Fire Pump	8				
<input type="checkbox"/> Water Storage Tank	9				
<input type="checkbox"/> Water Spray System	10				
<input type="checkbox"/> Foam Water Sprinkler System	11				
<input type="checkbox"/> Water Mist System	12				
<input type="checkbox"/> Concerns that are Not Deficiencies (i.e. Non-Sprinklered Areas)				<input type="checkbox"/> Yes	<input type="checkbox"/> No

*See "Deficiencies and Comments" section at end of each respective form.

Wet Pipe Fire Sprinkler System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Quarterly and Annual Report	1 of 3	
Property Information		Contractor or Licensed Owner Information		
Building Name		Name		
Address		Address		
City		City	St.	Zip
Contact Person		License #	Phone	
		<input type="checkbox"/> SFM <input type="checkbox"/> CSLB	Job #	Misc.

Riser Information			Main Drain Test (Annual)				
Riser No.	Location	Riser Diameter	Main Drain Diameter	Initial Static Pressure	Residual Pressure	Final Static Pressure	P,F,N/A

This building has more than 5 risers. See additional AES 2.9 form attached. Number of AES 2.9 forms attached

Quarterly Inspections									
		I = Inspection	T = Test	M = Maintenance	P = Pass			F = Fail	N/A = Not Applicable
Item		Description	NFPA 25 CA ed. Reference	Date	Date	Date	Date		
1.1	I	Control Valves – Identification Sign	13.3.1						
1.2	I	Control Valves – Inspection	13.3.2						
1.3	I	Waterflow Alarm Devices	5.2.5						
1.4	I	Supervisory Devices	5.2.5						
1.5	I	Gauges (Wet Pipe Systems)	5.2.4.1						
1.6	I	Enter Water Supply Pressure Below Riser Check	5.2.4.1	psi	psi	psi	psi		
1.7	I	Enter Water Supply Pressure Above Riser Check	5.2.4.1	psi	psi	psi	psi		
1.8	I	Pressure Readings Acceptable	5.2.4.1						
1.9	I	Hydraulic Design Information Sign <i>(For Hydraulically Designed Systems)</i>	5.2.6						
1.10	I	General Information Sign <i>(Not Required for System prior to 2007 Edition of NFPA 13)</i>	5.2.8						
1.11	I	Heat Tape	5.2.7						
1.12	I	Spare Sprinklers	5.2.1.4						
1.13	I	Fire Department Connections	13.7						
1.14	I	Alarm Valves – Exterior Inspection	13.4.1						
1.15	I	Pressure Reducing Valves	13.5.1.1						
1.16	I	Backflow Preventers	13.6.1						
1.17	I	Small Hose Connections - Hose Valve*	5.1.6, 13.5.2 13.5.5.1						
1.18	I	PRV – Fire Sprinkler Systems	13.5.1.1						

* Small hose connections are hose valves and optional hose supplied by the fire sprinkler system. They do not include Class I, II, or III standpipe systems.

Wet Pipe Fire Sprinkler System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Quarterly and Annual Report	2 of 3
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Job #	
City			

ANNUAL INSPECTION, TESTING, AND MAINTENANCE
Include ALL Quarterly Inspections

I = Inspection T = Test M = Maintenance P = Pass F = Fail N/A = Not Applicable

Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
1.19	I	Sprinklers	5.2.1			
1.20	I	Buildings (Freeze Protection)	4.1.1.1		Owner's Responsibility	
1.21	I	Pipe and Fittings	5.2.2			
1.22	I	Hangers	5.2.3			
1.23	I	Seismic Braces	5.2.3			
2.1	T	Field Service Test Required <i>(Send Report to Fire Code Official)</i>	5.3.1		If REQUIRED, Enter 'F' until results are returned from Lab	
2.2	T	Recalled Sprinklers <i>If not present = Pass; If present = Fail</i>	Title 19 904.1(c)			
2.3	T	Water Flow Alarm Devices <i>90 sec. maximum - (Enter Time)</i>	5.3.3 13.2.6		sec.	
2.4	T	Main Drain Test <i>(Enter Data on Page 1 of this Form)</i>	13.2.5 13.3.3.4			
2.5	T	Control Valve - Position	13.3.3.2			
2.6	T	Control Valve – Operation	13.3.3.1			
2.7	T	Supervisory Devices	13.3.3.5			
2.8	T	Backflow Preventer Assemblies	13.6.2			
2.9	T	Small Hose Connections* <i>w/PRV Hose Valves – Partial Flow Test</i>	13.5.2.3 13.5.3.3			
2.10	T	PRV – Fire Sprinkler Systems	13.5.1.3			
3.1	M	Control Valves	13.3.4			
3.2	M	Small Hose Connections*	13.5.6.3			
3.3	M	Obstruction Investigation required <i>(If "Yes", see Deficiencies and Comments Section for Results.)</i>	14.3		<input type="checkbox"/> Yes <input type="checkbox"/> No	
3.4	M	System Returned to Service	4.5.3		<input type="checkbox"/> Yes <input type="checkbox"/> No	

* Small hose connections are hose valves and optional hose supplied by the fire sprinkler system. They do not include Class I, II, or III standpipe systems.

D = Deficiency C = Comment (Indicate type)

Item	Date	Riser	D	C	Deficiencies and Comments
<i>Indicate all equipment, devices and parts that were repaired or replaced</i>					

Wet Pipe Fire Sprinkler System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	5-Year Report	1 of 3	
Property Information		Contractor or Licensed Owner Information		
Building Name		Name		
Address		Address		
City		City	St.	Zip
Contact Person		License #	Phone	
		<input type="checkbox"/> SFM	Job #	
	<input type="checkbox"/> CSLB	Misc.		

Riser Information				Main Drain Test (ANNUAL)			
Riser No.	Location	Riser Diameter	Main Drain Diameter	Initial Static Pressure	Residual Pressure	Final Static Pressure	P, F, N/A

This building has more than 5 risers. See additional AES 2.9 form attached. Number of AES 2.9 forms attached:

5-Year INSPECTION, TESTING, AND MAINTENANCE						
Includes ALL Quarterly and Annual Inspections, Tests, and Maintenance Items						
I = Inspection T = Test M = Maintenance				P = Pass F = Fail N/A = Not Applicable		
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P, F, N/A
1.1	I	Control Valves – Identification Sign	13.3.1			
1.2	I	Control Valves – Inspection	13.3.2			
1.3	I	Waterflow Alarm Devices	5.2.5			
1.4	I	Supervisory Devices	5.2.5			
1.5	I	Gauges (Wet Pipe Systems)	5.2.4.1			
1.6	I	Hydraulic Design Information Sign <i>(For Hydraulically Designed Systems)</i>	5.2.6			
1.7	I	Enter Water Supply Pressure Below Riser Check	5.2.4.1			psi
1.8	I	Enter Water Supply Pressure Above Riser Check	5.2.4.1			psi
1.9	I	Pressure Readings Acceptable	5.2.4.1			
1.10	I	General Information Sign <i>(Not Required for System Prior to 2007 Edition NFPA 13)</i>	5.2.8			
1.11	I	Heat Tape	5.2.7			
1.12	I	Spare Sprinklers	5.2.1.4			
1.13	I	Fire Department Connections	13.7			
1.14	I	Alarm Valves – Exterior Inspection	13.4.1			
1.15	I	Pressure Reducing Valves	13.5.1.1			
1.16	I	Backflow Preventers	13.6.1			

Wet Pipe Fire Sprinkler System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	5 Year Report	2 of 3
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Job #	
City			

ANNUAL INSPECTION, TESTING, AND MAINTENANCE						
Include ALL Quarterly Inspections (See AES 2.1)						
I = Inspection		T = Test		M = Maintenance		P = Pass F = Fail N/A = Not Applicable
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
1.17	I	Small Hose Connections - Hose Valve*	5.1.6, 13.5.2 13.5.5.1			
1.18	I	PRV – Fire Sprinkler Systems	13.5.1.1			
1.19	I	Buildings (Freeze Protection)	4.1.1.1		Owner's Responsibility	
1.20	I	Sprinklers	5.2.1			
1.21	I	Sprinklers - Accessible Concealed Space	5.2.1.1.6			
1.22	I	Pipe and Fittings	5.2.2			
1.23	I	Pipe and Fittings - Accessible Concealed Space	5.2.2.3			
1.24	I	Hangers	5.2.3			
1.25	I	Hangers - Accessible Concealed Space	5.2.3.3			
1.26	I	Seismic Braces	5.2.3			
1.27	I	Seismic Braces - Accessible Concealed Space	5.2.3.3			
1.28	I	Unsprinklered Areas	CFC 901.4		<input type="checkbox"/> Yes <input type="checkbox"/> No	
2.1	T	Field Service Test Required <i>Send Report to Fire Code Official</i>	5.3.1		If REQUIRED, Enter 'F' until results are returned from Lab	
2.2	T	Recalled Sprinklers If not present = Pass; If present = Fail	Title 19 904.1(c)			
2.3	T	Water Flow Alarm Devices 90 secs max. Enter time	5.3.3 13.2.6		sec.	
2.4	T	Main Drain Test (Enter data on Page 1 of this form)	13.2.5 13.3.3.4			
2.5	T	Control Valve - Position	13.3.3.2			
2.6	T	Control Valve – Operation	13.3.3.1			
2.7	T	Supervisory Devices	13.3.3.5			
2.8	T	Backflow Preventer Assemblies	13.6.2			
2.9	T	Small Hose Connections* w/PRV Hose Valves – Partial Flow Test	13.5.2.3 13.5.3.3			
2.10	T	PRV – Fire Sprinkler Systems	13.5.1.3			
2.11	T	Pressure Gauges - Calibration	5.3.2			
2.12	T	Small Hose Connections*	13.5.6.2.2			

* Small hose connections are hose valves and optional hose supplied by the fire sprinkler system. They do not include Class I, II, or III standpipe systems.

Dry Pipe Fire Sprinkler System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Quarterly and Annual Report	1 of 3	
Property Information		Contractor or Licensed Owner Information		
Building Name		Name		
Address		Address		
City		City	St.	Zip
Contact Person		License #	Phone	
Phone		<input type="checkbox"/> SFM <input type="checkbox"/> CSLB	Job #	Misc.

Riser Information			Main Drain Test (Annual)				
Riser No.	Location	Riser Diameter	Main Drain Diameter	Initial Static Pressure	Residual Pressure	Final Static Pressure	P,F,N/A

This building has more than 5 risers. See additional AES 2.9 form attached. Number of AES 2.9 forms attached:

Quarterly Inspections							
I = Inspection T = Test M = Maintenance			P = Pass F = Fail N/A = Not Applicable				
Item		Description	NFPA 25 CA ed. Reference	Date	Date	Date	Date
1.1	I	Control Valves – Identification Sign	13.3.1				
1.2	I	Control Valves – Inspection	13.3.2				
1.3	I	Waterflow Alarm Devices	5.2.5				
1.4	I	Supervisory Devices	5.2.5				
1.5	I	Gauges (Dry Pipe Systems) <i>Pass = Normal Pressures</i>	5.2.4.2, 5.2.4.3 5.2.4.4 13.4.4.1.2				
1.6	I	Air Pressure	5.2.4.2, 5.2.4.3 5.2.4.4 13.4.4.2.5.1	psi	psi	psi	psi
1.7	I	Water Supply Pressure	5.2.4.2 13.4.4.2.5.1	psi	psi	psi	psi
1.8	I	Hydraulic Design Information Sign <i>(For Hydraulically Designed Systems)</i>	5.2.6				
1.9	I	General Information Sign <i>(Not Required for System Prior to 2007 Edition of NFPA 13)</i>	5.2.8				
1.10	I	Heat Tape	5.2.7				
1.11	I	Spare Sprinklers	5.2.1.4				
1.12	I	Fire Department Connections	13.7				
1.13	I	Dry Pipe Valves – Exterior Inspection	13.4.4.1.4				
1.14	I	Pressure Reducing Valves	13.5.1				
1.15		Backflow Preventers	13.6.1				
1.16		PRV – Fire Sprinkler Systems	13.5.1				

Dry Pipe Fire Sprinkler System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Quarterly and Annual Report	3 of 3
-------------------------------------------	-------------------------------------------------------------------------------------------	----------------------------------------	---------------

Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Job #
City		

ANNUAL INSPECTION, TESTING, AND MAINTENANCE <i>Include ALL Quarterly Inspections</i>

I = Inspection T = Test M = Maintenance P = Pass F = Fail N/A = Not Applicable						
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
3.1	M	Control Valves	13.3.4			
3.2	M	Maintenance	13.4.4.3			
3.3	M	Dry Pipe Valve Interior Cleaned	13.4.4.3.1			
3.4	M	Low Points in System Drained	13.4.4.3.2			
3.5	M	Backflow Preventer	13.6.3			
3.6	M	Obstruction Investigation Required <i>(If "Yes", see Deficiencies and Comments Section for Results.)</i>	14.3		<input type="checkbox"/> Yes <input type="checkbox"/> No	
3.7	M	System Returned to Service	4.5.3 15.7		<input type="checkbox"/> Yes <input type="checkbox"/> No	

D = Deficiency C = Comment (Indicate type)

Item	Date	Riser	D	C	Deficiencies and Comments <i>Indicate all equipment, devices and parts that were repaired or replaced</i>

Check here if additional Deficiencies and Comments are listed on Form AES9. Number attached: _____
 See Correction Form AES 10 for corrected deficiencies. Number attached: _____

I hereby certify that the fire protection equipment listed above has been fully inspected, tested, and maintained on this date by the company indicated above, in accordance with CCR, Title 19, Sections 901 to 906 and that the equipment is fully operable except as noted in the "Deficiencies and Comments" section of this form.

Check box if Annual Inspection, Testing & Maintenance Items are Completed in the Indicated Quarter								
Quarter	1st	<input type="checkbox"/> Annual	2nd	<input type="checkbox"/> Annual	3rd	<input type="checkbox"/> Annual	4th	<input type="checkbox"/> Annual
Date								
Print Name								
Signature								

Dry Pipe Fire Sprinkler System		California Code of Regulations - Title 19 Inspection, Testing, and Maintenance		5-Year Report	1 of 3
Property Information				Contractor or Licensed Owner Information	
Building Name				Name	
Address				Address	
City				St.	Zip
Contact Person		License #		Phone	
Phone		<input type="checkbox"/> SFM		Job #	
		<input type="checkbox"/> CSLB		Misc.	

Riser Information				Main Drain Test (ANNUAL)			
Riser No.	Location	Riser Diameter	Main Drain Diameter	Initial Static Pressure	Residual Pressure	Final Static Pressure	P, F, N/A

This building has more than 5 risers. See additional AES 2.9 form attached Number of AES 2.9 forms attached

5-Year INSPECTION, TESTING, AND MAINTENANCE						
<i>Includes ALL Quarterly and Annual Inspections, Tests, and Maintenance Items</i>						
I = Inspection T = Test M = Maintenance				P = Pass F = Fail N/A = Not Applicable		
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P, F, N/A
1.1	I	Control Valves – Identification Sign	13.3.1			
1.2	I	Control Valves – Inspection	13.3.2			
1.3	I	Waterflow Alarm Devices	5.2.5			
1.4	I	Supervisory Alarm Devices	5.2.5			
1.5	I	Gauges (Dry Pipe Systems) <i>Pass = Normal Pressures</i>	5.2.4.2 5.2.4.3 5.2.4.4 13.4.4.1.2			
1.6	I	Air Pressure	5.2.4.2 5.4.2.3 5.2.4.4 13.4.4.2.5.1		psi	
1.7	I	Water Supply Pressure	5.2.4.2 13.4.4.2.5.1		psi	
1.8	I	Hydraulic Design Information Sign <i>(For Hydraulically Designed Systems)</i>	5.2.6			
1.9	I	General Information Sign <i>(Not Required for System Prior to 2007 Edition NFPA 13)</i>	5.2.8			
1.10	I	Heat Tape	5.2.7			
1.11	I	Spare Sprinklers	5.2.1.4			
1.12	I	Fire Department Connections	13.7			
1.13	I	Dry Pipe Valves – Exterior Inspection	13.4.4.1.4			
1.14	I	Pressure Reducing Valves	13.5.1.1			
1.15	I	Backflow Preventers	13.6.1			

Dry Pipe Fire Sprinkler System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	5-Year Report	2 of 3
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Job #	
City			

ANNUAL INSPECTION, TESTING, AND MAINTENANCE						
Include ALL Quarterly Inspections (See AES 2.3)						

I = Inspection		T = Test		M = Maintenance		P = Pass F = Fail N/A = Not Applicable	
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A	
1.16	I	PRV - Fire Sprinkler Systems	13.5.1				
1.17	I	Buildings (Freeze protection)	4.1.1.1		Owner's Responsibility		
1.18	I	Sprinklers	5.2.1				
1.19	I	Sprinklers - Concealed Space	5.2.1.1.6				
1.20	I	Pipe and Fittings	5.2.2				
1.21	I	Pipe and Fittings - Concealed Space	5.2.2.3				
1.22	I	Hangers	5.2.3				
1.23	I	Hangers - Concealed Space	5.2.3.3				
1.24	I	Seismic Braces	5.2.3				
1.25	I	Seismic Braces - Concealed Space	5.2.3.3				
1.26	I	Dry Pipe Valves - Interior Inspection	13.4.4.1.5				
1.27	I	Strainer, Filters, Restricted Orifices Inspection	13.4.4.1.6				
2.1	T	Dry Pipe Valve Trip Test - Full Flow	13.4.4.2.2.2				
2.2	T	Field Service Test Required Send Report to Fire Code Official	5.3.1		If REQUIRED, Enter 'F' until results are returned from Lab		
2.3	T	Recalled Sprinklers If not present = Pass; If present = Fail	Title 19 904.1(c)				
2.4	T	Water Flow Alarm Devices 90 secs max. Enter time	5.3.3 13.2.6		sec.		
2.5	T	Main Drain Test (Enter data on Page 1 of this form)	13.2.5 13.3.3.4				
2.6	T	Priming Water Level Test	13.4.4.2.1				
2.7	T	Valve Trip Time	13.4.4.2.5.2		sec		
2.8	T	Trip Air Pressure	13.4.4.2.5.1		psi		
2.9	T	Quick Opening Device Test	13.4.4.2.4				
2.10	T	Low Air Pressure Alarm Test	13.4.4.2.6				
2.11	T	Low Temperature Alarm Test	13.4.4.2.7				
2.12	T	Automatic Air Pressure Maintenance Device Test	13.4.4.2.8				
2.13	T	Control Valve – Operation	13.3.3.1				
2.14	T	Valve Supervisory Devices	13.3.3.5				
2.15	T	Backflow Preventer Assemblies	13.6.2				

Dry Pipe Fire Sprinkler System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	5-Year Report	3 of 3
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Job #	
City			

ANNUAL INSPECTION, TESTING, AND MAINTENANCE <i>Include ALL Quarterly Inspections (See AES 2.3)</i>						
I = Inspection T = Test M = Maintenance				P = Pass F = Fail N/A = Not Applicable		
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
2.16	T	PRV – Full Flow Test	13.5.1.2			
2.17	T	Pressure Gauges - Calibration	5.3.2			
3.1	M	Air Leakage Test	13.4.4.2.9			
3.2	M	Check Valves - Internal Inspection	13.4.2			
3.3	M	Control Valves	13.3.4			
3.4	M	Maintenance	13.4.4.3			
3.5	M	Dry Pipe Valve Interior Cleaned	13.4.4.3.1			
3.6	M	Auxiliary Drains in System Drained	13.4.4.3.2			
3.7	M	Backflow Preventer	13.6.3			
3.8	M	FDC - Backflush	14.3.2.3 14.3.2.4			
3.9	M	Internal Pipe Inspection - See Deficiencies and Comments Section for Results.	14.2		<input type="checkbox"/> Yes <input type="checkbox"/> No	
3.10	M	Obstruction Investigation Required. If "Yes", See Deficiencies and Comments Section for Results	14.3			
3.11	M	System Returned to Service	4.5.3 15.7		<input type="checkbox"/> Yes <input type="checkbox"/> No	

D = Deficiency C = Comment (Indicate type)					
Item	Date	Riser	D	C	Deficiencies and Comments <i>Indicate all equipment, devices and parts that were repaired or replaced</i>

Check here if additional Deficiencies and Comments are listed on Form AES9. Number attached: _____
 See Correction Form AES 10 for corrected deficiencies. Number attached: _____

I hereby certify that the fire protection equipment listed above has been fully inspected, tested, and maintained on this date by the company indicated above, in accordance with CCR, Title 19, Sections 901 to 906 and that the equipment is fully operable except as noted in the "Deficiencies and Comments" section of this form.

Print Name	
Signature	Date

Pre-Action Fire Sprinkler System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Quarterly and Annual Report	1 of 3	
Property Information		Contractor or Licensed Owner Information		
Building Name		Name		
Address		Address		
City		City	St.	Zip
Contact Person		License #	Phone	
Phone		<input type="checkbox"/> SFM	Job #	
		<input type="checkbox"/> CSLB	Misc.	

Riser Information			Main Drain Test (Annual)				
Riser No.	Location	Riser Diameter	Main Drain Diameter	Initial Static Pressure	Residual Pressure	Final Static Pressure	P,F,N/A

This building has more than 5 risers. See additional AES 2.9 form attached. Number of AES 2.9 forms attached:

NOTE: For Pre-Action Sprinkler Systems used as Foam Water Systems, add Supplemental Form AES 8

Quarterly Inspections							
I = Inspection T = Test M = Maintenance			P = Pass F = Fail N/A = Not Applicable				
Item		Description	NFPA 25 CA ed. Reference	Date	Date	Date	Date
1.1	I	Control Valves – Identification Sign	13.3.1				
1.2	I	Control Valves – Inspection	13.3.2				
1.3	I	Waterflow Alarm Devices	5.2.5				
1.4	I	Supervisory Alarm Devices	5.2.5				
1.5	I	Gauges (Pre-Action Valves) <i>Pass = Normal Pressures</i>	13.4.3.1.3				
1.6	I	Air Pressure	13.4.3.1.4	psi	psi	psi	psi
1.7	I	Water Supply Pressure	13.4.3.1.3.1	psi	psi	psi	psi
1.8	I	Detection System (Pilot Line) Air Pressure	13.4.3.1.5	psi	psi	psi	psi
1.9	I	Hydraulic Design Information Sign <i>(For Hydraulically Designed Systems)</i>	5.2.6				
1.10	I	General Information Sign <i>(Not Required for System Prior to 2007 Edition of NFPA 13)</i>	5.2.8				
1.11	I	Heat Tape	5.2.7				
1.12	I	Spare Sprinklers	5.2.1.4				
1.13	I	Fire Department Connections	13.7				
1.14	I	Pre-action Valves – Exterior Inspection	13.4.3.1.6				
1.15	I	Pressure Reducing Valves	13.5.1				
1.16	I	Master Pressure Reducing Valves	13.5.4.1				
1.17	I	Backflow Preventers	13.6.1				

Pre-Action Fire Sprinkler System Water	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	5-Year Report	1 of 3
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Address	
City	License #	City	St. Zip
Contact Person	<input type="checkbox"/> SFM	Phone	
Phone	<input type="checkbox"/> CSLB	Job #	
		Misc.	

Riser Information			Main Drain Test (ANNUAL)				
Riser No.	Location	Riser Diameter	Main Drain Diameter	Initial Static Pressure	Residual Pressure	Final Static Pressure	P, F, N/A
<input type="checkbox"/> This building has more than 5 risers. See additional AES 2.9 form attached				Number of AES 2.9 forms attached:			

NOTE: For Pre-Action Sprinkler Systems used as Foam Water Systems, add Supplemental Form AES 8
5-Year Inspection, Testing, and Maintenance
Includes ALL Quarterly and Annual Inspections, Tests, and Maintenance Items

I = Inspection T = Test M = Maintenance				P = Pass F = Fail N/A = Not Applicable		
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P, F, N/A
1.1	I	Control Valves – Identification Sign	13.3.1			
1.2	I	Control Valves – Inspection	13.3.2			
1.3	I	Waterflow Alarm Devices	5.2.5			
1.4	I	Supervisory Alarm Devices	5.2.5			
1.5	I	Gauges (PreAction Valves) <i>Pass = Normal Pressures</i>	13.4.3.1.3			
1.6	I	Water Supply Pressure	13.4.3.1.3.1			psi
1.7	I	Air Pressure	13.4.3.1.4			psi
1.8	I	Detection System (Pilot Line) Air Pressure	13.4.3.1.5			psi
1.9	I	Hydraulic Design Information Sign <i>(For Hydraulically Designed Systems)</i>	5.2.6			
1.10	I	General Information Sign <i>(Not Required for System Prior to 2007 Edition NFPA 13)</i>	5.2.8			
1.11	I	Heat Tape	5.2.7			
1.12	I	Spare Sprinklers	5.2.1.4			
1.13	I	Fire Department Connections	13.7			
1.14	I	Preaction Valves – Exterior Inspection	13.4.3.1.6			
1.15	I	Pressure Reducing Valves	13.5.1.1			
1.16	I	Master Pressure Reducing Valves	13.5.4.1			
1.17	I	Backflow Preventers	13.6.1			

Pre-Action Fire Sprinkler System Water	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	5-Year Report	2 of 3
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Job #	
City			

5-Year Inspection, Testing, and Maintenance <i>Includes ALL Quarterly and Annual Inspections, Tests, and Maintenance</i>						
I = Inspection		T = Test		M = Maintenance		P = Pass F = Fail N/A = Not Applicable
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
1.18	I	Low Temperature Alarm	13.4.3.1.2			
1.19	I	Buildings (Freeze Protection)	4.1.1.1		Owner's Responsibility	
1.20	I	Sprinklers	5.2.1			
1.21	I	Sprinklers - Accessible Concealed Space	5.2.1.1.6			
1.22	I	Pipe and Fittings	5.2.2			
1.23	I	Pipe and Fittings - Accessible Concealed Space	5.2.2.3			
1.24	I	Hangers	5.2.3			
1.25	I	Hangers - Accessible Concealed Space	5.2.3.3			
1.26	I	Seismic Braces	5.2.3			
1.27	I	Seismic Braces - Accessible Concealed Space	5.2.3.3			
1.28	I	Strainer, Filters, Restricted Orifices Inspection	13.4.4.1.6			
2.1	T	Field Service Test Required Send Report to Fire Code Official	5.3.1		If REQUIRED, Enter 'F' until results are returned from Lab	
2.2	T	Recalled Sprinklers If not present = Pass; If present = Fail	Title 19 904.1(c)			
2.3	T	Waterflow Alarm Devices 90 sec max. Enter time	5.3.3 13.2.6		sec.	
2.4	T	Main Drain Test (Enter data on Page 1 of this form)	13.2.5 13.3.3.4			
2.5	T	Priming Water Level Test	13.4.3.2.1			
2.6	T	Valve Trip Test - Full Flow	13.4.3.2.2 13.4.3.2.2.4			
2.7	T	Valve Trip Time	13.4.3.2.12		sec	
2.8	T	Manual Actuation Device Test	13.4.3.2.9			
2.9	T	Air Leakage Test	13.4.3.2.6			
2.10	T	Low Air Pressure Alarm Test	13.4.3.2.13			
2.11	T	Low Temperature Alarm Test	13.4.3.2.14			
2.12	T	Automatic Air Pressure Maintenance Device Test	13.4.3.2.15			
2.13	T	Control Valve – Operation	13.3.3			
2.14	T	Valve Supervisory Devices	13.3.3.5			
2.15	T	Backflow Preventer Assemblies	13.6.2			

Pre-Action Fire Sprinkler System Water	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	5-Year Report	3 of 3
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Job #	
City			

5-Year Inspection, Testing, and Maintenance						
Includes ALL Quarterly and Annual Inspections, Tests, and Maintenance Items						
I = Inspection		T = Test		M = Maintenance		P = Pass F = Fail N/A = Not Applicable
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
2.16	T	PRV – Fire Sprinkler Systems	13.5.1.3			
2.17	T	Pressure Gauges <i>Calibrated or Replaced</i>	5.3.2			
3.1	M	Control Valves	13.3.4			
3.2	M	Check Valves - Internal Inspection	13.4.2.2			
3.3	M	Repair Air Leaks	13.4.3.3.1			
3.4	M	Interior Inspected and Cleaned <i>(All Preaction Valves)</i>	13.4.3.1.7 13.4.3.1.7.1 13.4.3.3.2			
3.5	M	Low Points in System Drained	13.4.3.3.3			
3.6	M	Additional Manufacturer's Maintenance Requirements Satisfied	13.4.3.3.4			
3.7	M	FDC - Backflush	14.3.2.3 14.3.2.4			
3.8	M	Internal Pipe Inspection - See Deficiencies and Comments Section for Results.	14.2		<input type="checkbox"/> Yes <input type="checkbox"/> No	
3.9	M	Obstruction Investigation required. If "Yes", See Deficiencies and Comments Section for Results	14.3			
3.10	M	System Returned to Service	4.5.3 13.4.3.2.10 15.7		<input type="checkbox"/> Yes <input type="checkbox"/> No	

D = Deficiency C = Comment (Indicate type)					
Item	Date	Riser	D	C	Deficiencies and Comments
<i>Indicate all equipment, devices and parts that were repaired or replaced</i>					

<input type="checkbox"/> Check here if additional Deficiencies and Comments are listed on Form AES 9.	Number attached:
<input type="checkbox"/> See Correction Form AES 10 for corrected deficiencies.	Number attached:

I hereby certify that the fire protection equipment listed above has been fully inspected, tested, and maintained on this date by the company indicated above, in accordance with CCR, Title 19, Sections 901 to 906 and that the equipment is fully operable except as noted in the "Deficiencies and Comments" section of this form.

Print Name	
Signature	Date

Deluge Sprinkler Systems Water Spray	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Quarterly and Annual Report	1 of 4
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Address	
City	License #	City	St. Zip
Contact Person	<input type="checkbox"/> SFM	Phone	Job #
Phone	<input type="checkbox"/> CSLB		Misc.

Riser Information			Main Drain Test (Annual)				
Riser No.	Location	Riser Diameter	Main Drain Diameter	Initial Static Pressure	Residual Pressure	Final Static Pressure	P,F,N/A

This building has more than 5 risers. See additional AES 2.9 form attached. Number of AES 2.9 forms attached: _____

Quarterly Inspections							
I = Inspection T = Test M = Maintenance			P = Pass F = Fail N/A = Not Applicable				
Item		Description	NFPA 25 CA ed. Reference	Date	Date	Date	Date
1.1	I	Control Valves – Identification Sign	13.3.1				
1.2	I	Control Valves – Inspection	13.3.2				
1.3	I	Waterflow Alarm Devices	5.2.5				
1.4	I	Supervisory Alarm Devices	5.2.5				
1.5	I	Gauges (Deluge Valves) <i>Pass = Normal Pressures</i>	13.4.3.1.3				
1.6	I	Water Supply Pressure	13.4.3.1.3.1	psi	psi	psi	psi
1.7	I	Detection System (Pilot Line) Air Pressure	13.4.3.1.5	psi	psi	psi	psi
1.8	I	Pressure Readings Acceptable					
1.9	I	Hydraulic Design Information Sign <i>(For Hydraulically Designed Systems)</i>	5.2.6				
1.10	I	General Information Sign <i>(Not Required for System Prior to 2007 Edition of NFPA 13)</i>	5.2.8				
1.11	I	Fire Department Connections	13.7				
1.12	I	Deluge Valves – Exterior Inspection	10.2.2 13.4.3.1.6				
1.13	I	Pressure Reducing Valves	13.5.1.1				
1.14	I	Backflow Preventers	13.6.1				
1.15	I	Drainage	10.2.8				
1.16	I	Detection Systems	10.2.3				
1.17	I	Master Pressure Reducing Valves	13.5.4.1				
1.18	I	UHSWSS - Detectors <i>(Monthly)</i>	10.4.2	Jan	Apr	Jul	Oct
				Feb	May	Aug	Nov
				Mar	Jun	Sep	Dec

Deluge Sprinkler Systems Water Spray	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Quarterly and Annual Report	3 of 4
-------------------------------------------------	-------------------------------------------------------------------------------------------	----------------------------------------	---------------

Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Job #
City		

ANNUAL INSPECTION, TESTING, AND MAINTENANCE						
Include ALL Quarterly Inspections						

I = Inspection T = Test M = Maintenance			P = Pass F = Fail N/A = Not Applicable			
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
2.22	T	Water Spray System Test	10.3 13.4.3.2			
2.23	T	Waterflow Alarm	5.3.3			
2.24	T	UHSWSS	10.4			
2.25	T	Detection Systems	10.2.3			
2.26	T	Check Valves <i>(Includes Detector Check Valves)</i>	13.4.2.1			
3.1	M	Control Valves	13.3.4			
3.2	M	Air Leaks Repaired	13.4.3.3.1			
3.3	M	Deluge Valve Interior Inspected and Cleaned <i>(For Valves that Must Be Internally Reset)</i>	13.4.3.1.7 13.4.3.3.2			
3.4	M	Auxiliary Drains in System Drained	13.4.3.3.3			
3.5	M	Additional Manufacturer's Maintenance Requirements Satisfied	13.4.3.3.4			
3.6	M	Strainers <i>(Baskets/Screen)</i>	10.2.1.4 10.2.4.6 10.2.7			
3.7	M	Water Spray System	10.2.1.4 13.4.3.3			
3.8	M	Deluge Valve	10.2.2 13.4.3.3			
3.9	M	Detection Systems	10.2.3			
3.10	M	Backflow Preventer	13.6.3			
3.11	M	Check Valves <i>(Includes Detector Check Valves)</i>	13.4.2			
3.12	M	Obstruction Investigation Required <i>(If "Yes", See Deficiencies and Comments Section for Results.)</i>	14.3		<input type="checkbox"/> Yes <input type="checkbox"/> No	
3.13	M	System Returned to Service	4.5.3 13.4.3.2.10 15.7		<input type="checkbox"/> Yes <input type="checkbox"/> No	

D = Deficiency C = Comment (Indicate type)

Item	Date	Riser	D	C	Deficiencies and Comments
Indicate all equipment, devices and parts that were repaired or replaced					

Deluge Sprinkler Systems Water Spray		California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	5-Year Report	1 of 4	
Property Information			Contractor or Licensed Owner Information		
Building Name			Name		
Address			Address		
City			City	St.	Zip
Contact Person			License #	Phone	
Phone			<input type="checkbox"/> SFM	Job #	
			<input type="checkbox"/> CSLB	Misc.	

Riser Information				Main Drain Test (ANNUAL)			
Riser No.	Location	Riser Diameter	Main Drain Diameter	Initial Static Pressure	Residual Pressure	Final Static Pressure	P, F, N/A

This building has more than 5 risers. See additional AES 2.9 form attached. Number of AES 2.9 forms attached: _____

5-Year Inspection, Testing, and Maintenance <i>Includes ALL Quarterly and Annual Inspections, Tests, and Maintenance Items</i>						
I = Inspection T = Test M = Maintenance				P = Pass F = Fail N/A = Not Applicable		
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P, F, N/A
1.1	I	Control Valves – Identification Sign	13.3.1			
1.2	I	Control Valves – Inspection	13.3.2			
1.3	I	Waterflow Alarm Devices	5.2.5			
1.4	I	Supervisory Alarm Devices	5.2.5			
1.5	I	Gauges (Prection/Deluge Valves) <i>Pass = Normal Pressures</i>	13.4.3.1.3			
1.6	I	Water Supply Pressure	13.4.3.1.3.1			psi
1.7	I	Detection System (Pilot Line) Air Pressure	13.4.3.1.5			psi
1.8	I	Hydraulic Design Information Sign <i>(For Hydraulically Designed Systems)</i>	5.2.6			
1.9	I	General Information Sign <i>(Not Required for System Prior to 2007 Edition NFPA 13)</i>	5.2.8			
1.10	I	Fire Department Connections	13.7			
1.11	I	Deluge Valves – Exterior Inspection	10.2.2 13.4.3.1.6			
1.12	I	Pressure Reducing Valves	13.5.1.1			
1.13	I	Backflow Preventers	13.6.1			
1.14	I	Pipe and Fittings	10.2.4 10.2.4.1			
1.15	I	Drainage	13.2.4			
1.16	I	Detection Systems	10.2.3			
1.17	I	Master Pressure Reducing Valves	13.5.4.1			

Deluge Sprinkler Systems Water Spray	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	5-Year Report	2 of 4
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Job #	
City			

5-Year Inspection, Testing, and Maintenance						
<i>Includes ALL Quarterly and Annual Inspections, Tests, and Maintenance Items</i>						
I = Inspection		T = Test		M = Maintenance		
P = Pass F = Fail N/A = Not Applicable						
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
1.18	I	UHSWSS - Detectors	10.4.2			
1.19	I	Buildings (Freeze Protection)	4.1.1.1		Owner's Responsibility	
1.20	I	Low Temperature Alarm	13.4.3.1.2			
1.21	I	Nozzles	10.2.1.6 10.2.5			
1.22	I	Pipe and Fittings	10.2.4.1			
1.23	I	Hangers and Supports	10.2.4.2			
1.24	I	Deluge Valve - Interior inspection	13.4.3.1.7			
2.1	T	Waterflow Alarm Devices 90 sec max. Enter time	5.3.3 13.2.6		sec.	
2.2	T	Main Drain Test (Enter Data on Page 1 of this Form)	13.2.5 13.3.3.4			
2.3	T	Priming Water Level Test	13.4.3.2.1			
2.4	T	Valve Trip Test - Full Flow	10.2.2 13.4.3.2			
2.5	T	Valve Trip Time	10.3.4.2 13.4.3.2.12		sec	
2.6	T	Pressure at the Hydraulically Most Remote Nozzle or Sprinkler	10.3.4.4.1 13.4.3.2.7.1		psi	
2.7	T	Pressure at Deluge Valve	10.3.4.4.2 13.4.3.2.7.2		psi	
2.8	T	Pressure Readings Acceptable	10.3.4.4.3 13.4.3.2.7.3		<input type="checkbox"/> Yes <input type="checkbox"/> No	
2.9	T	Water Discharge Pattern at Nozzle or Sprinkler	10.3.4.3			
2.10	T	Multiple System Test	10.3.5 13.4.3.2.8			
2.11	T	Manual Actuation Device Test	10.3.6 13.4.3.2.6			
2.12	T	Deluge Valve - Interior inspection	13.4.3.1.7			
2.13	T	Low Air Pressure Alarm Test	13.4.3.2.13			
2.14	T	Low Temperature Alarm Test	13.4.3.2.14			
2.15	T	Automatic Air Pressure Maintenance Device Test	13.4.3.2.15			
2.16	T	Control Valve - Position	13.3.3			
2.17	T	Control Valve – Operation	13.3.3			
2.18	T	Valve Supervisory Devices	13.3.3.5			

Deluge Sprinkler Systems Water Spray	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	5-Year Report	3 of 4
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Job #	
City			

5-Year Inspection, Testing, and Maintenance <i>Includes ALL Quarterly and Annual Inspections, Tests, and Maintenance Items</i>						
I = Inspection T = Test M = Maintenance			<i>P = Pass F = Fail N/A = Not Applicable</i>			
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
2.19	T	Backflow Preventer Assemblies	13.6.2			
2.20	T	Pressure Reducing Valves	13.5.1.2			
2.21	T	Flushing of Connection to Riser <i>(Part of Annual Test)</i>	10.3 Table 10.1.1.2			
2.22	T	Nozzles	10.2.16 10.3.4.3			
2.23	T	Water Spray System Test	10.3 13.4.3.2			
2.24	T	Waterflow Alarm	5.3.3			
2.25	T	UHSWSS	10.4			
2.26	T	Detection Systems	10.2.3			
2.27	T	Check Valves <i>(Includes Detector Check Valves)</i>	13.4.2.1			
3.1	M	Control Valves	10.1.5 13.3.4			
3.2	M	Repair Air Leaks	13.4.3.3.1			
3.3	M	Interior Inspected and Cleaned <i>(All Deluge Valves)</i>	13.4.3.1.7 13.4.3.3.2			
3.4	M	Low Points in System Drained	13.4.3.3.3			
3.5	M	Additional Manufacturer's Maintenance Requirements Satisfied	13.4.3.3.4			
3.6	M	Strainers, Filters, Restricted Orifices, and Diaphragm Chambers <i>(Includes Baskets and Screens)</i>	10.2.1.4 10.2.7 13.4.3.1.8			
3.7	M	Water Spray System/Deluge Valve	10.2.1.4 10.2.2 13.4.3.3			
3.8	M	Detection Systems	10.2.3			
3.9	M	Backflow Preventer	13.6.3			
3.10	M	Check Valves <i>(Includes Detector Check Valves)</i>	13.4.2.2			
3.11	M	FDC - Backflush	14.3.2.3 14.3.2.4			
3.12	M	Obstruction Investigation Required. If "Yes", See Deficiencies and Comments Section for Results	14.3		<input type="checkbox"/> Yes <input type="checkbox"/> No	
3.13	M	System Returned to Service	4.5.3 13.4.3.2.10 15.7		<input type="checkbox"/> Yes <input type="checkbox"/> No	

Dry Chemical Pre-Engineered Fire Extinguishing System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Semi-Annual Report	1 of 2
--------------------------------------------------------------	-------------------------------------------------------------------------------------------	---------------------------	---------------

Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Address
City	License #	City St. Zip
Contact Person	<input type="checkbox"/> SFM	Phone
Phone	<input type="checkbox"/> CSLB	Job #
		Misc.

System Information			
--------------------	--	--	--

Cylinder Size(s)	Last Hydrostatic Test Date(s)	Duct Size(s)
System Location	System Mfr.	Model #
Protected Area Type	Dimensions	
Fuel/Air Shut Off:	<input type="checkbox"/> Mechanical <input type="checkbox"/> Electrical	

Fixed Temperature Sensing Elements (Such as Fusible Links)							
---------------------------------------------------------------	--	--	--	--	--	--	--

Quantity	Temp	Mfg Date	Install Date	Quantity	Temp	Mfg Date	Install Date

Inspection, Testing, and Maintenance						
--------------------------------------	--	--	--	--	--	--

I = Inspection T = Test M = Maintenance P = Pass F = Fail N/A = Not Applicable

Item		Description	NFPA 17 CA ed. Reference	Date	Comments Only	P,F,N/A
1.1	I	Manual Actuators are Unobstructed (i.e. Remote Pull Station)	11.2.1.1(2)			
1.2	I	Tamper Indicators & Seals Intact	11.2.1.1(3)			
1.3	I	Maintenance Tag in Place	11.2.1.1(4) CCR T-19 §906			
1.4	I	No Obvious Physical Damage	11.2.1.1(5)			
1.5	I	Gauge Readings within Proper Limits (Stored Pressure)	11.2.1.1(6)			
1.6	I	Blow-Off Caps in Place & Undamaged	11.2.1.1(7)			
1.7	I	Protected Equipment or Hazard Has Not Been Replaced, Modified or Relocated	11.2.1.1(8)			
2.1	T	Automatic Detection, Manual Actuation, Shutdowns and Auxiliary Equipment Functioned Correctly	11.3.1.4			
2.2	T	Alarm Signals Functioned Correctly	11.3.1.4			
2.3	T	Releasing Devices Operable	11.3.1.4			
3.1	M	All Agent Containers within Acceptable Hydrostatic Test Dates	11.5.1(1)			
3.2	M	All Auxiliary Pressure Containers and/or Hose Assemblies within Acceptable Hydrostatic Test Dates	11.5.1(2)(3)			
3.3	M	Cartridge Weights within Acceptable Limits	11.3.1.1(2)			
3.4	M	Nozzles are Correct, Clean & Properly Aimed	11.3.1.1(2)			
3.5	M	Expellant Gas containers are Full and Free of Defects	11.3.1.1(2)			
3.6	M	Hose Assemblies Checked	11.3.1.1(2)			
3.7	M	Distribution Piping Unobstructed and Contiguous	11.3.1.1(3)			

Standpipe and Hose System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Quarterly and Annual Report	1 of 3	
Property Information		Contractor or Licensed Owner Information		
Building Name		Name		
Address		Address		
City		City	St.	Zip
Contact Person		License #	Phone	
Phone		<input type="checkbox"/> SFM <input type="checkbox"/> CSLB	Job #	Misc.

Riser Information			Main Drain Test (Annual)				
Riser No.	Location	Riser Diameter	Main Drain Diameter	Initial Static Pressure	Residual Pressure	Final Static Pressure	P,F,N/A

This building has more than 5 risers. See additional AES 2.9 form attached. Number of AES 2.9 forms attached: _____

Quarterly Inspections							
I = Inspection T = Test M = Maintenance				P = Pass F = Fail N/A = Not Applicable			
Item		Description	NFPA 25 CA ed. Reference	Date	Date	Date	Date
1.1	I	Control Valves – Identification Sign	13.3.1				
1.2	I	Control Valves – Inspection	13.3.2				
1.3	I	Waterflow Alarm Devices	5.2.5				
1.4	I	Supervisory Devices	5.2.5				
1.5	I	Gauges <i>Pass = Normal Pressures</i>	6.2.1 6.2.2				
1.6	I	Water Supply Pressure Below Dry Pipe or Preaction Valve	6.2.1 6.2.2	psi	psi	psi	psi
1.7	I	Water Supply Pressure Above Dry Pipe or Preaction Valve	6.2.1 6.2.2	psi	psi	psi	psi
1.8	I	Pressure at Top of Standpipe Riser	6.2.1 6.2.2 13.2.7	psi	psi	psi	psi
1.9	I	Air/Nitrogen Pressure	6.21 6.22 13.2.7	psi	psi	psi	psi
1.10	I	Pressure at Discharge of Fire Pump or Pressure Tank	6.2.1 6.2.2 13.2.7	psi	psi	psi	psi
1.11	I	Pressure Readings Acceptable	6.22 13.2.7				
1.12	I	Standpipe Hose Valves	13.5.6.1				
1.13	I	Hydraulic Design Information Sign <i>(For Hydraulically Designed Systems)</i>	6.2.3				
1.14	I	Heat Tape	5.2.7				
1.15	I	Fire Department Connections	13.7				
1.16	I	Pressure Reducing Valves	13.5.1.1				

Standpipe and Hose System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Quarterly and Annual Report	2 of 3
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Job #	
City			

ANNUAL INSPECTION, TESTING, AND MAINTENANCE <i>Include ALL Quarterly Inspections</i>

I = Inspection T = Test M = Maintenance			P = Pass F = Fail N/A = Not Applicable			
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
1.17		Backflow Preventers	13.6.1			
1.18	I	Buildings (Freeze Protection)	4.1.1.1		Owner's Responsibility	
1.19	I	Pipe and Fittings	5.2.2			
1.20	I	Hangers	5.2.3			
1.21	I	Seismic Braces	5.2.3			
1.22	I	Hose Connections	6.2.1 Table 6.1.2			
1.23	I	Cabinet	6.2.1 Table 6.1.2			
1.24	I	Hose	6.2.1 Table 6.1.2			
1.25	I	Hose Storage Device	6.2.1 Table 6.1.2 NFPA 1962			
1.26	I	Hose Nozzle	6.2.1 Table 6.1.2			
2.1	T	Control Valve – Position	6.2.1 13.3.3.1			
2.2	T	Control Valve – Operation	6.2.1 13.3.3.2			
2.3	T	Supervisory Devices	13.3.3.5			
2.4	T	Waterflow Alarm Devices <i>90 sec. maximum - (Enter Time)</i>	6.3.3 13.2.6		sec.	
2.5	T	Main Drain Test <i>(Enter Data on Page 1 of this Form)</i>	13.2.5 13.3.3.4			
2.6	T	Hose Rack Hose Valve <i>(Partial Flow Test)</i>	13.5.3.3			
2.7	T	Pressure Reducing Hose Valve <i>(Partial Flow Test)</i>	13.5.2.3			
2.8	T	Backflow Preventer Assemblies	13.6.2			
2.9	T	Class I & III Hose Valve Test	13.5.6.2.1			
2.10	T	Class II Hose Valve Test	13.5.6.2.2			
3.1	M	Control Valves	13.3.4			
3.2	M	Hose Valves	13.5.6.3			
3.3	M	Obstruction Investigation Required <i>(If "Yes", See Deficiencies and Comments Section for Results.)</i>	14.3		<input type="checkbox"/> Yes <input type="checkbox"/> No	
3.4	M	System Returned to Service	4.5.3 15.7		<input type="checkbox"/> Yes <input type="checkbox"/> No	

Standpipe and Hose System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	5-Year Report	1 of 4
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Address	
City	License #	City	St. Zip
Contact Person	<input type="checkbox"/> SFM	Phone	
Phone	<input type="checkbox"/> CSLB	Job #	
		Misc.	

Type of Standpipe System	Class of Standpipe System
<input type="checkbox"/> Manual Wet	<input type="checkbox"/> Class I
<input type="checkbox"/> Manual Dry	<input type="checkbox"/> Class II
<input type="checkbox"/> Automatic Wet	<input type="checkbox"/> Class III
<input type="checkbox"/> Automatic Dry	
<input type="checkbox"/> Semi-Automatic Dry	
<input type="checkbox"/> Combined Sprinkler/Standpipe	

Riser Information				Main Drain Test (ANNUAL)			
Riser No.	Location	Riser Diameter	Main Drain Diameter	Initial Static Pressure	Residual Pressure	Final Static Pressure	P, F, N/A
<input type="checkbox"/> This building has more than 5 risers. See additional AES 2.9 form attached.				Number of AES 2.9 forms attached:			

5-Year Inspection, Testing, and Maintenance						
<i>Includes ALL Quarterly and Annual Inspections, Tests, and Maintenance Items</i>						
I = Inspection T = Test M = Maintenance				P = Pass F = Fail N/A = Not Applicable		
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P, F, N/A
1.1	I	Control Valves – Identification Sign	13.3.1			
1.2	I	Control Valves – Inspection	13.3.2			
1.3	I	Waterflow Alarm Devices	5.2.5			
1.4	I	Supervisory Alarm Devices	5.2.5			
1.5	I	Pressure Gauges <i>Pass = Normal Pressures</i>	6.2.1 6.2.2			
1.6	I	Water Supply Pressure Below Dry Pipe or Preaction Valve	6.2.1 6.2.2			psi
1.7	I	Water Supply Pressure Above Dry Pipe or Preaction Valve	6.2.1 6.2.2			psi
1.8	I	Pressure at Top of Standpipe Riser	6.2.1 6.2.2, 13.2.7			psi
1.9	I	Air/Nitrogen Pressure	6.2.1 6.2.2, 13.2.7			psi
1.10	I	Pressure at Discharge of Fire Pump or Pressure Tank	6.2.1 6.2.2, 13.2.7			psi
1.11	I	Pressure Readings Acceptable	6.2.2 13.2.7			
1.12	I	Hydraulic Design Information Sign <i>(For Hydraulically Designed Systems)</i>	6.2.3			
1.13	I	Heat Tape	5.2.7			

Standpipe and Hose System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	5-Year Report	2 of 4
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Job #	
City			

5-Year Inspection, Testing, and Maintenance <i>Includes ALL Quarterly and Annual Inspections, Tests, and Maintenance Items</i>						
I = Inspection T = Test M = Maintenance			P = Pass F = Fail N/A = Not Applicable			
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
1.14	I	Standpipe Hose Valves	13.5.6.1			
1.15	I	Pressure Reducing Hose Valves	13.5.2.1			
1.16	I	Pressure Reducing Valves	13.5.1.1			
1.17	I	Fire Department Connections	13.7			
1.18	I	Backflow Preventers	13.6.1			
1.19	I	Buildings (Freeze Protection)	4.1.1.1		Owner's Responsibility	
1.20	I	Pipe and Fittings	6.2.1 Table 6.1.2			
1.21	I	Hangers	6.2.1			
1.22	I	Seismic Braces	6.2.1			
1.23	I	Hose Connection	6.2.1 Table 6.1.2			
1.24	I	Cabinet	6.2.1 Table 6.1.2			
1.25	I	Hose	6.2.1 Table 6.1.2			
1.26	I	Hose Storage Device	6.2.1 Table 6.1.2			
1.27	I	Hose Nozzle	6.2.1 Table 6.1.2			
2.1	T	Control Valve - Position	6.2.1 13.3.3.1			
2.2	T	Control Valve - Operation	6.2.1 13.3.3.2			
2.3	T	Supervisory Devices	13.3.3.5			
2.4	T	Waterflow Alarm Devices 90 sec max. Enter time	5.3.3 13.2.6		sec.	
2.5	T	Main Drain Test (Enter Data on Page 1 of this Form)	13.2.5 13.3.3.4			
2.6	T	Standpipe Flow Test	6.3.1		Provide results in table on 1st page.	
2.7	T	Standpipe Hydrostatic Test	6.3.2			
2.8	T	Hose Rack Assembly Flow Test	13.5.3.2			
2.9	T	Backflow Preventer Assemblies	13.6.2			
2.10	T	Pressure Reducing Hose Valves	13.5.2.2			
2.11	T	Pressure Reducing Valves	13.5.3.2			
2.12	T	Pressure Gauges	6.3.4			

Private Fire Service Main	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Quarterly and Annual Report	1 of 2
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Address	
City		City	St. Zip
Contact Person	License #	Phone	
Phone	<input type="checkbox"/> SFM	Job #	
	<input type="checkbox"/> CSLB	Misc.	

Quarterly Inspections							
I = Inspection T = Test M = Maintenance				P = Pass F = Fail N/A = Not Applicable			
Item		Description	NFPA 25 CA ed. Reference	Date	Date	Date	Date
1.1	I	Control Valves – Identification Sign	13.3.1				
1.2	I	Control Valves – Inspection	13.3.2				
1.3	I	Hose Houses	7.2.2.7				
1.4	I	Fire Department Connections	13.7				
1.5	I	Pressure Reducing Valves	13.5.1.1				
1.6	I	Backflow Preventers	13.6.1				
1.7	I	Supervisory Devices	13.3.3.5.1				
1.8	I	Monitor Nozzles	7.2.2.6				

ANNUAL INSPECTION, TESTING, AND MAINTENANCE						
Include ALL Quarterly Inspections						
I = Inspection T = Test M = Maintenance				P = Pass F = Fail N/A = Not Applicable		
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
1.9	I	Hydrants (Dry Barrel and Wall)	7.2.2.4 Table 7.2.2.4			
1.10	I	Hydrants (Wet Barrel)	7.2.2.5 Table 7.2.2.5			
1.11	I	Mainline Strainers	7.2.2.3 Table 7.2.2.3			
1.12	I	Piping (Exposed)	7.2.2.1 Table 7.2.2.1.2			
1.13	I	Piping (Underground)	7.3.1			
1.14	I	Hose	NFPA 1962			
2.1	T	Control Valve - Position	13.3.3.1			
2.2	T	Control Valve - Operation	13.3.3			
2.3	T	Monitor Nozzles	7.3.3			
2.4	T	Hydrants - Flush	7.3.2			
2.5	T	Supervisory Devices	13.3.3.5			
2.6	T	Backflow Preventer Assemblies	13.6.2			
2.7	T	Pressure Reducing Valve (Partial Flow Test)	13.5.1.3			
3.1	M	Control Valves	13.3.4			
3.2	M	Mainline Strainers	7.2.2.3			

Private Fire Service Main	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	5-Year Report	1 of 2
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Address	
City	License #	City	St. Zip
Contact Person	<input type="checkbox"/> SFM	Phone	
Phone	<input type="checkbox"/> CSLB	Job #	
		Misc.	

5-Year Inspection, Testing, and Maintenance
Includes ALL Quarterly and Annual Inspections, Tests, and Maintenance Items

I = Inspection T = Test M = Maintenance		<i>P = Pass F = Fail N/A = Not Applicable</i>				
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P, F, N/A
1.1	I	Control Valves – Identification Sign	13.3.1			
1.2	I	Control Valves – Inspection	13.3.2			
1.3	I	Hose Houses	7.2.2.7			
1.4	I	Fire Department Connections	13.7			
1.5	I	Pressure Reducing Valves	13.5.1.1			
1.6	I	Backflow Preventers	13.6.1			
1.7	I	Monitor Nozzles	7.2.2.6			
1.8	I	Hydrants <i>(Dry Barrel and Wall)</i>	7.2.2.4 Table 7.2.2.4			
1.9	I	Hydrants <i>(Wet Barrel)</i>	7.2.2.5 Table 7.2.2.5			
1.10	I	Mainline Strainers	7.2.2.3 Table 7.2.2.3			
1.11	I	Piping <i>(Exposed)</i>	7.2.2.1 Table 7.2.2.1.2			
1.12	I	Hose	7.1.4 NFPA 1962			
2.1	T	Control Valve - Positions	13.3.3.1			
2.2	T	Control Valve - Operation	13.3.3			
2.3	T	Monitor Nozzles	7.3.3			
2.4	T	Hydrants - Flush	7.3.2			
2.5	T	Supervisory Devices	13.3.3.5			
2.6	T	Backflow Preventer Assemblies	13.6.2			
2.7	T	Piping <i>(Exposed and Underground Evaluation)</i>	7.3.1.1		Record results in Deficiencies and Comments Section	
2.8	T	Water Supply Evaluation <i>(If Required by 7.3.1.2)</i>	7.3.1.2		Record results below in Table for Water Supply Test Evaluation	
2.9	T	Pressure Reducing Valve <i>Full Flow Test</i>	13.5.1.2			
2.10	T	Hose	7.1.4 NFPA 1962			

Standpipe and Hose System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	5-Year Report	2 of 2
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Job #	
City			



5-Year Inspection, Testing, and Maintenance
Includes ALL Quarterly and Annual Inspections, Tests, and Maintenance Items

I = Inspection		T = Test		M = Maintenance		<i>P = Pass F = Fail N/A = Not Applicable</i>	
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A	
3.1	M	Control Valves	13.3.4				
3.2	M	Mainline Strainers	7.2.2.3 Table 7.2.2.3				
3.3	M	Hose Houses	7.2.2.7 Table 7.2.2.7				
3.4	M	Hydrants	7.4.2				
3.5	M	Monitor Nozzles	7.4.3				
3.6	M	FDC - Backflush	14.3.2.3 14.3.2.4				
3.7	M	Internal Pipe Inspection: See Deficiencies and Comments Section for Results	14.2				
3.8	M	Obstruction Investigation Required. If "Yes", See Deficiencies and Comments Section for Results	14.3		<input type="checkbox"/> Yes <input type="checkbox"/> No		
3.9	M	System Returned to Service	4.5.3 15.7		<input type="checkbox"/> Yes <input type="checkbox"/> No		

If required by 7.3.1.2 - Table for Water Supply Test Evaluation (Item 2.8)

Flow Rate (gpm)		Static Pressure (psi)	
Hose Stream Allowance (gpm)		Residual Pressure (psi)	
Total System Demand (gpm)		Flow Rate (gpm)	
Required Pressure at Source (psi)		Available Pressure at Total System Demand (psi)	

D = Deficiency C = Comment (Indicate type)

Item	Date	Riser	D	C	Deficiencies and Comments <i>Indicate all equipment, devices and parts that were repaired or replaced</i>

<input type="checkbox"/> Check here if additional Deficiencies and Comments are listed on Form AES 9.	Number attached:
<input type="checkbox"/> See Correction Form AES 10 for corrected deficiencies.	Number attached:

I hereby certify that the fire protection equipment listed above has been fully inspected, tested, and maintained on this date by the company indicated above, in accordance with CCR, Title 19, Sections 901 to 906 and that the equipment is fully operable except as noted in the "Deficiencies and Comments" section of this form.

Print Name	
Signature	Date

Diesel Fire Pump	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Weekly Report	1 of 4
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Address	
City		City	St. Zip
Contact Person	License #	Phone	
Phone	<input type="checkbox"/> SFM	Job #	
	<input type="checkbox"/> CSLB	Misc.	

Pump #	Pump and Driver Information				
Pump Manufacturer		Max Suction Pressure	psi	Driver Mfr.	
Pump Model		Max psi (shutoff)	psi	Driver Model	
Pump Serial #		Rated Capacity	gpm	Driver Rated RPM	
Rated RPM		Rated Pressure	psi	Fuel Tank Capacity	gal.
Controller Mfr		150% Rated Capacity	gpm		
Controller Model		Rated Pressure @ Rated Capacity	psi		
Controller S/N					
Where the pump and driver manufacturer's recommendations are not available, use the items in this form, which reference NFPA 25, Table 8.5.3. If the manufacturer's recommendations are available, then those recommendations are to be used.					

I = Inspection T = Test M = Maintenance				P = Pass F = Fail N/A = Not Applicable				
Year		Month	Week	1	2	3	4	5
Item	Description		NFPA 25 CA ed Reference	Date	Date	Date	Date	Date
Fire Pump Start/Stop Pressures								
1.1	T	Fire Pump Start Pressure	8.3.2.8(1)(f)	psi	psi	psi	psi	psi
1.2	T	Fire Pump Stop Pressure	8.3.2.8(1)(f)	psi	psi	psi	psi	psi
1.3	T	Pressure Maintenance Pump Start Pressure	8.3.2.8(1)(g)	psi	psi	psi	psi	psi
1.4	T	Pressure Maintenance Pump Stop Pressure	8.3.2.8(1)(g)	psi	psi	psi	psi	psi
Pump House								
1.5	I	Pump House Heating and Ventilating Louvers	8.2.2(1)(a) 8.2.2(1)(b)					
Fire Pump System								
1.6	I	Control Valves - Identification Sign	13.3.1					
1.7	I	Control Valves - Inspection	13.3.2					
1.8	I	Pump Suction, Discharge & Bypass Valves Open	8.2.2(2)(a)					
1.9	I	Normally Closed Valves are Closed (Test Header/Venturi Meter)	8.2.2(2)(g) 13.3.2.2					
1.10	I	Valve Supervisory Devices	5.2.5					
1.11	M	Control Valve Maintenance	13.3.4					
1.12	I	Piping is Free of Leaks	8.2.2(2)(b)					
1.13	I	Suction Reservoir is Full	8.2.2(2)(e)					
1.14		Suction Line Pressure Gauge Reading within Acceptable Range	8.2.2(2)(c)					
	I	Suction Pressure Reading	8.2.2(2)(c)	psi	psi	psi	psi	psi

Diesel Fire Pump	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Weekly Report	2 of 4
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Job #	
City			

Item		Description	Week NFPA 25 CA ed. Reference	1	2	3	4	5
				Date	Date	Date	Date	Date
1.15	I	System Line Pressure Gauge Reading within Acceptable Range	8.2.2(2)(d)					
	I	System Pressure Reading	8.2.2(2)(d)	psi	psi	psi	psi	psi
1.16	I	Wet Pit Suction Screens Unobstructed and in Place	8.2.2(2)(f)					
1.17	I	Verify Pump Packing Glands for Slight Discharge (Pump Not Running)	8.2.2(2)(h)					
1.18	I	Suction Pressure Gauge Reading (Pump Running)	8.3.2.8(1)(a)	psi	psi	psi	psi	psi
1.19	I	Discharge Pressure Gauge Reading (Pump Running)	8.3.2.8(1)(a)	psi	psi	psi	psi	psi
1.20	I	Check Pump Packing Glands for Slight Discharge (Pump Running)	8.3.2.8(1)(b)					
1.21	I	Adjust Gland Nuts if Necessary	8.3.2.8(1)(c)					
1.22	I	Check for Unusual Noise or Vibration	8.3.2.8(1)(d)					
1.23	I	Check Packing Boxes, Bearings, or Pump Casing for Overheating	8.3.2.8(1)(e)					
1.24	I	Circulation Relief Valve Operating Properly (No Flow)	8.3.3.2(1)(a)					
1.25	I	Pressure Relief Valve Operating Properly (No Flow)	8.3.3.2(1)(b)					
1.26	I	Pressure Relief Valve Operating Properly (Flowing)	8.3.3.3.1 8.3.3.3.2 13.5.7.2					
1.27	I	Observe Time for Engine to Crank	8.3.2.8(d)(a)	sec	sec	sec	sec	sec
1.28	I	Observe Time for Engine to Reach Running Speed	8.3.2.8(3)(b)	sec	sec	sec	sec	sec
1.29	I	Record Time Controller is on First Step (Reduced Voltage or Reduced Current Starting)	8.3.2.8(3)(b)	sec	sec	sec	sec	sec
1.30	I	Record Time Pump Runs After Starting (Automatic Stop Controllers)	8.3.2.8(2)(c)	min	min	min	min	min
1.31	I	Observe & Record the Following While Engine Running:						
		Engine Oil Pressure Gauge	8.3.2.8(3)(c)	psi	psi	psi	psi	psi
		Speed Indicator Reading	8.3.2.8(3)(c)	rpm	rpm	rpm	rpm	rpm
		Water Temperature	8.3.2.8(3)(c)	°F	°F	°F	°F	°F
		Oil Temperature	8.3.2.8(3)(c)	°F	°F	°F	°F	°F
1.32	T	Pump Operation (No Flow Condition - 30 min.)	8.3.2.4					
1.33	I	Record Any Abnormalities (Use Comments and Deficiencies)	8.3.2.8(3)(d)					
Electrical System Conditions								
1.34	I	Controller "Power On" Power Light is Illuminated	8.2.2(3)(a)					
1.35	I	Transfer Switch Pilot Light is Illuminated	8.2.2(3)(b)					

Diesel Fire Pump	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Weekly Report	3 of 4
-------------------------	------------------------------------------------------------------------------------------	----------------------	---------------

Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Job #
City		

Item		Description	Week NFPA 25 CA ed. Reference	1	2	3	4	5
				Date	Date	Date	Date	Date
1.36	I	Isolating Switch is Closed - Standby (Emergency) Source	8.2.2(3)(c)					
1.37	I	Electrical System: General Inspection	Table 8.1.2					
1.38	I	Reverse Phase Alarm Pilot Light is Off or Normal Phase Rotation Pilot Light is On	8.2.2(3)(d)					
1.39	I	Oil Level in Vertical Motor Sight Glass is Within Acceptable Range	8.2.2(3)(e)					
1.40	I	Power to Pressure Maintenance (Jockey) Pump is Provided	8.2.2(3)(f)					
1.41	I	Controller Selector Switch is in "Auto" Position	8.2.2(4)(b)					
1.42	I	Batteries (2) Voltage Readings are Within Acceptable Range	8.2.2(4)(c)					
1.43	I	Batteries (2) Charging Current Readings are Within Acceptable Range	8.2.2(4)(d)					
1.44	I	Batteries (2) Pilot Lights are On or Battery Failure (2) Lights are Off	8.2.2(4)(e)					
1.45	I	All Alarm Pilot Lights are Off	8.2.2(4)(f)					
1.46	I	Electrolyte Level in Batteries is Within Acceptable Range	8.2.2(4)(k) Table 8.1.2					
1.47	I	Battery Terminals are Free from Corrosion	8.2.2(4)(l)					
1.48	I	Cranking Voltage 9V on 12V System 18V on 24V System	Table 8.1.2					
Diesel Engine System								
1.49	I	Engine Running Time Meter is Reading	8.2.2(4)(g)					
1.50	I	Oil Level in Right Angle Gear Drive is within Acceptable Range	8.2.2(4)(h)					
1.51	I	Cooling Water Level is within Acceptable Range	8.2.2(4)(j)					
1.52	I	Water Jacket Heater is Operating	8.2.2(4)(m)					
1.53	I	Fuel: Tank Level (Two-Thirds Full)	Table 8.1.2 8.2.2(4)(a)					
1.54	I	Fuel: Tank Float Switch	Table 8.1.2					
1.55	I	Fuel: Solenoid Valve Operation	Table 8.1.2					
1.56	I	Fuel: Flexible Hoses and Connectors	Table 8.1.2					
1.57	I	Lubrication System: Oil level is within Acceptable Range	Table 8.1.2 8.2.2(4)(i)					
1.58	I	Cooling System: Level	Table 8.1.2					
1.59	I	Cooling System: Adequate Cooling Water to Heat Exchanger	Table 8.1.2 8.3.2.8(3)(e)					
1.60	I	Cooling System: Water Pumps	Table 8.1.2					

Diesel Fire Pump	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Weekly Report	4 of 4
-------------------------	------------------------------------------------------------------------------------------	----------------------	---------------

Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Job #
City		

Item		Description	Week NFPA 25 CA ed. Reference	1	2	3	4	5
				Date	Date	Date	Date	Date
1.61	I	Cooling System: Condition of Flexible Hoses and Connections	Table 8.1.2					
1.62	I	Cooling System: Jacket Water Heater	Table 8.1.2					
1.63	I	Exhaust System: Leakage	Table 8.1.2					
1.64	M	Control Maintenance	13.3.4					
1.65	M	Fuel: Water in System	Table 8.1.2					
1.66	M	Exhaust System: Drain Condensate Trap	Table 8.1.2					
1.67	M	Lubrication System: Lube Oil Heater	Table 8.1.2					
General Maintenance								
1.68	M	System Returned to Service	4.5.3 15.7					

D = Deficiency C = Comment (Indicate type)

Item	Date	Riser	D	C	<i>Deficiencies and Comments</i> <small>Indicate all equipment, devices and parts that were repaired or replaced</small>

- Check here if additional Deficiencies and Comments are listed on Form AES 9. Number attached:
- See Correction Form AES 10 for corrected deficiencies. Number attached:

I hereby certify that the fire protection equipment listed above has been fully inspected, tested, and maintained on this date by the company indicated above, in accordance with CCR, Title 19, Sections 901 to 906 and that the equipment is fully operable except as noted in the "Deficiencies and Comments" section of this form.

Week	1	2	3	4	5
Date					
Print Name					
Signature					

Diesel Fire Pump	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Annual Report	1 of 9
-------------------------	------------------------------------------------------------------------------------------	----------------------	---------------

Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Address
City	License #	City St. Zip
Contact Person	<input type="checkbox"/> SFM	Phone
Phone	<input type="checkbox"/> CSLB	Job #
		Misc.

Pump # Pump and Driver Information					
Pump Manufacturer		Max Suction Pressure	psi	Driver Mfr.	
Pump Model		Max psi (shutoff)	psi	Driver Model	
Pump Serial #		Rated Capacity	gpm	Driver Rated RPM	
Rated RPM		Rated Pressure	psi	Fuel Tank Capacity	gal.
Controller Mfr		150% Rated Capacity	gpm		
Controller Model		Rated Pressure @ Rated Capacity	psi		
Controller S/N					

Where the pump and driver manufacturer's recommendations are not available, use the items in this form, which reference NFPA 25, Table 8.5.3. If the manufacturer's recommendations are available, then those recommendations are to be used.

Annual Flow Test									
Churn (0%) 8.3.5.1	Flow (gpm)		Suction (psi)		Discharge (psi)		Net Pressure (psi)		Speed (rpm)
100% Rated Flow	Nozzle #	Size	Pitot Pressure	Flow (gpm)	Suction (psi)	Discharge (psi)	Net Pressure (psi)	Speed (rpm)	
	1								
	2								
	3								
	4								
	5								
	6								
150% Rated Flow	Nozzle #	Size	Pitot Pressure	Flow (gpm)	Suction (psi)	Discharge (psi)	Net Pressure (psi)	Speed (rpm)	
	1								
	2				Suction pressure at 150% of rated flow at least 0 psi? (8.1.6.1) <input type="checkbox"/> Yes <input type="checkbox"/> No				
	3				For pump systems installed per NFPA 20, using suction tanks where NFPA 20 permitted the suction pressure to be not less than 3 psi, is the suction pressure at least 3 psi? (8.1.6.2) <input type="checkbox"/> Yes <input type="checkbox"/> No				
	4								
	5								
	6								

Fire Pump Test Curves	
Manufacturer's shop test curve	1. 8.3.5.3(1)
Original adjusted fire pump curve using net pump pressures	2. 8.3.5.3(1)
Current adjusted fire pump curve using net pump pressures	3. 8.3.5.3(1)
Original unadjusted fire pump curve using net pump pressures	4. 8.3.5.3(1)
Current unadjusted fire pump curve using net pump pressures	5. 8.3.5.3(1)
Current unadjusted fire pump curve using total pump pressure + supply pressure	6. 8.3.5.7
Note: The fire pump nameplate data is permitted to be used if the manufacturer's shop test curve is unavailable. (8.3.5.3(2))	


Diesel Fire Pump	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Annual Report	2 of 9
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Job #	
City			

Test Results and Evaluation (8.3.5.7)				
Fire Protection System Demand Information			Fire Pump	
Type of System	Required Pressure at the Pump Discharge Flange (psi)	Required Flow (gpm)	Is the fire pump capable of supplying the system demand using the unadjusted pump curve?	
			<input type="checkbox"/> Yes	<input type="checkbox"/> No
			<input type="checkbox"/> Yes	<input type="checkbox"/> No
			<input type="checkbox"/> Yes	<input type="checkbox"/> No
			<input type="checkbox"/> Yes	<input type="checkbox"/> No
			<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are fire pump test results satisfactory?			<input type="checkbox"/> Yes	<input type="checkbox"/> No
			8.1.6	8.3.5.3
			8.3.5	8.3.5.4
			8.3.5.2.1	8.3.5.5
			8.3.5.6	8.3.5.7

Annual Fire Pump Inspection, Testing, and Maintenance						
Include ALL Monthly and Annual Inspection, Testing, and Maintenance Items						
I = Inspection T = Test M = Maintenance			P = Pass F = Fail N/A = Not Applicable			
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
Fire pump Start/Stop Pressures						
1.01	I	Fire Pump Start Pressure	8.3.2.8(1)(f)		psi	
1.02	I	Fire Pump Stop Pressure	8.3.2.8(1)(f)		psi	
1.03	I	Pressure Maintenance Pump Start Pressure	8.3.2.8(1)(g)		psi	
1.04	I	Pressure Maintenance Pump Stop Pressure	8.3.2.8(1)(g)		psi	
Pump House						
1.05	I	Pump House Heating and Ventilating Louvers. Illumination	8.2.2(1)(a) 8.2.2(1)(b) 8.3.4.3			
Fire Pump System						
1.06	I	Control Valves - Identification Sign	13.3.1			
1.07	I	Control Valves - Inspection	13.3.2			
1.08	I	Pump suction, Discharge & Bypass Valves Open	8.2.2(2)(a)			
1.09	I	Normally Closed Valves Are Closed <i>(Test Header/Venturi Meter)</i>	8.2.2(2)(g) 13.3.2.2			
1.10	I	Piping is Free of Leaks	8.2.2(2)(b)			
1.11	I	Suction Line Pressure Gauge Reading within Acceptable Range <i>(Same as Water Level in Tank or Static Pressure in Water Main)</i>	8.2.2(2)(c)			
	I	Suction Pressure Reading	8.2.2(2)(c)		psi	
1.12	I	Discharge Line Pressure Gauge Reading within Acceptable Range <i>(Same as Suction Gauge Reading)</i>	8.2.2(2)(d)			
	I	Discharge Pressure Reading	8.2.2(2)(d)		psi	
1.13	I	Suction Reservoir Full	8.2.2(2)(e)			

Diesel Fire Pump	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Annual Report	8 of 9
-------------------------	------------------------------------------------------------------------------------------	----------------------	---------------


Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Job #
City		



Curve Identification:
 1. Manufacturer's shop test curve
 2. Original adjusted fire pump curve
 3. Current adjusted fire pump curve

Diesel Fire Pump	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Annual Report	9 of 9
-------------------------	------------------------------------------------------------------------------------------	----------------------	---------------

Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Job #
City		



Curve Identification:
 4. Original unadjusted fire pump curve
 5. Current unadjusted fire pump curve
 6. Current unadjusted fire pump curve using total pump pressure + supply pressure

Electric Fire Pump	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Monthly Report	1 of 3
---------------------------	------------------------------------------------------------------------------------------	-----------------------	---------------

Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Address
City		City St. Zip
Contact Person	License #	Phone
Phone	<input type="checkbox"/> SFM	Job #
	<input type="checkbox"/> CSLB	Misc.

Pump #	Pump and Driver Information				
--------	-----------------------------	--	--	--	--

Pump Manufacturer		Max Suction Pressure	psi	Driver Mfr.	
Pump Model		Max psi (shutoff)	psi	Driver Model	
Pump Serial #		Rated Capacity	gpm	Driver Rated RPM	
Rated RPM		Rated Pressure	psi	Full Load Amp (FLA)	Amp
Controller Mfr.		150% Rated Capacity	gpm	Rated Voltage	Volts
Controller Model		Rated Pressure @ Rated Capacity	psi	Service Factor (SF)	
Controller S/N					

Where the pump and driver manufacturer's recommendations are not available, use the items in this form, which reference NFPA 25, Table 8.1.2 and Table 8.1.1.2. If the manufacturer's recommendations are available, then those recommendations are to be used.

I = Inspection T = Test M = Maintenance P = Pass F = Fail N/A = Not Applicable

Item		Description	Year	Month	NFA 25 CA ed Reference	1	2	3	4	5	6
						Month/Day	Month/Day	Month/Day	Month/Day	Month/Day	Month/Day
Fire Pump Start/Stop Pressures											
1.1	T	Fire Pump Start Pressure			8.3.2.8(1)(f)	psi	psi	psi	psi	psi	psi
1.2	T	Fire Pump Stop Pressure			8.3.2.8(1)(f)	psi	psi	psi	psi	psi	psi
1.3	T	Pressure Maintenance Pump Start Pressure			8.3.2.8(1)(g)	psi	psi	psi	psi	psi	psi
1.4	T	Pressure Maintenance Pump Stop Pressure			8.3.2.8(1)(g)	psi	psi	psi	psi	psi	psi
Pump House											
1.5	I	Pump House Heating and Ventilating Louvers			8.2.2(1)(a) 8.2.2(1)(b)						
Fire Pump System											
1.6	I	Control Valves - Identification Sign			13.3.1						
1.7	I	Control Valves - Inspection			13.3.2						
1.8	I	Pump Suction, Discharge & Bypass Valves Open			8.2.2(2)(a)						
1.9	I	Normally Closed Valves are Closed (Test Header/Venturi Meter)			8.2.2(2)(g) 13.3.2.2						
1.10	I	Valve Supervisory Devices			5.2.5						
1.11	I	Piping is Free of Leaks			8.2.2(2)(b)						
1.12	I	Suction Reservoir is Full			8.2.2(2)(e)						
1.13	I	Suction Line Pressure Gauge Reading within Acceptable Range			8.2.2(2)(c)						
	I	Suction Pressure Reading				psi	psi	psi	psi	psi	psi

Electric Fire Pump	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Monthly Report	2 of 3
---------------------------	------------------------------------------------------------------------------------------	-----------------------	---------------

Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Job #
City		

Item		Year	Description	Month	NFPA 25 CA ed. Reference	1	2	3	4	5	6
						Month/Day	Month/Day	Month/Day	Month/Day	Month/Day	Month/Day
1.14	I		System Line Pressure Gauge Reading within Acceptable Range		8.2.2(2)(d)						
	I		System Pressure Reading			psi	psi	psi	psi	psi	psi
1.15	I		Wet Pit Suction Screens Unobstructed and in Place		8.2.2(2)(f)						
1.16	I		Verify Pump Packing Glands for Slight Discharge (Pump Not Running)		8.2.2(2)(h)						
1.17	I		Pump Operation (No Flow - 10 min.)		8.3.2.3						
1.18	I		Observe Time for Motor to Accelerate to Full Speed		8.3.2.8(2)(a)						
1.19	I		Check Pump Packing Glands for Slight Discharge (Pump Running)		8.3.2.8(1)(b)						
1.20	I		Suction Pressure Gauge Reading (Pump Running)		8.3.2.8(1)(a)	psi	psi	psi	psi	psi	psi
1.21	I		Discharge Pressure Gauge Reading (Pump Running)		8.3.2.8(1)(a)	psi	psi	psi	psi	psi	psi
1.22	I		Pressure Readings Acceptable								
1.23	I		Adjust Gland Nuts if Necessary		8.3.2.8(1)(c)						
1.24	I		Check for Unusual Noise or Vibration		8.3.2.8(1)(d)						
1.25	I		Check Packing Boxes, Bearings, or Pump Casing for Overheating		8.3.2.8(1)(e)						
1.26	I		Circulation Relief Valve Operating Properly (No Flow)		8.3.3.2(1)(a) 13.5.7.1.1						
1.27	I		Record Time Controller is on First Step (Reduced Voltage or Reduced Current Starting)		8.3.2.8(3)(b)	sec	sec	sec	sec	sec	sec
1.28	I		Record Time Pump Runs After Starting (Automatic Stop Controllers)		8.3.2.8(2)(c)	min	min	min	min	min	min
Electrical System Conditions											
1.29	I		Controller "Power On" Power Light is Illuminated		8.2.2(3)(a)						
1.30	I		Engine Generator Sets (Monthly)		NFPA 110						
1.31	I		Transfer Switch Pilot Light is Illuminated		8.2.2(3)(b)						
1.32	I		Isolating Switch is Closed - Standby (Emergency) Source		8.2.2(3)(c)						
1.33	I		Reverse Phase Alarm Pilot Light is Off, or, Normal Phase Rotation Pilot Light is On		8.2.2(3)(d)						
1.34	I		Oil Level in Vertical Motor Sight Glass is Within Acceptable Range		8.2.2(3)(e)						
1.35	I		Exercise Isolating Switch Circuit Breaker		Table 8.1.2						
1.36	T		Power to Pressure Maintenance (Jockey) Pump is Provided		8.2.2(3)(f)						
General Maintenance											
1.37	M		System Returned to Service		4.5.3 15.7						

Electric Fire Pump	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Annual Report	1 of 7
---------------------------	------------------------------------------------------------------------------------------	----------------------	---------------

Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Address
City		City St. Zip
Contact Person	License #	Phone
Phone	<input type="checkbox"/> SFM	Job #
	<input type="checkbox"/> CSLB	Misc.

Pump #	Pump and Driver Information
---------------	------------------------------------

Pump Manufacturer		Max Suction Pressure	psi	Driver Mfr.	
Pump Model		Max psi (shutoff)	psi	Driver Model	
Pump Serial #		Rated Capacity	gpm	Driver Rated RPM	
Rated RPM		Rated Pressure	psi	Full Load Amp (FLA)	Amp
Controller Mfr		150% Rated Capacity	gpm	Rated Voltage	Volts
Controller Model		Rated Pressure @ Rated Capacity	psi	Service Factor (SF)	
Controller S/N					

Where the pump and driver manufacturer's recommendations are not available, use the items in this form, which reference NFPA 25, Table 8.5.3. If the manufacturer's recommendations are available, then those recommendations are to be used.

Annual Flow Test

Churn (0%) 8.3.5.1	Flow (gpm)	Suction (psi)	Discharge (psi)	Net Pressure (psi)	Speed (rpm)
	Phase	Volts	Amps	V x A	Rated V x FLA x SF
	A-B				
	B-C				
	C-A				
	8.3.5.5 V x A acceptable? <input type="checkbox"/> Yes <input type="checkbox"/> No			8.3.5.6 Voltage acceptable? <input type="checkbox"/> Yes <input type="checkbox"/> No	

100% Rated Flow	Nozzle #	Size	Pitot Pressure	Flow (gpm)	Phase	Volts	Amps	V x A	Rated V x FLA x SF	
	1									
	2									
	3									
	4				8.3.5.5 V x A acceptable? <input type="checkbox"/> Yes <input type="checkbox"/> No					
	5				8.3.5.6 Voltage acceptable? <input type="checkbox"/> Yes <input type="checkbox"/> No					
	6									

150% Rated Flow	Nozzle #	Size	Pitot Pressure	Flow (gpm)	Phase	Volts	Amps	V x A	Rated V x FLA x SF	
	1									
	2									
	3									
	4				8.3.5.5 V x A acceptable? <input type="checkbox"/> Yes <input type="checkbox"/> No					
	5				8.3.5.6 Voltage acceptable? <input type="checkbox"/> Yes <input type="checkbox"/> No					
	6				Suction pressure at 150% of rated flow at least 0 psi? <input type="checkbox"/> Yes <input type="checkbox"/> No					
For pump systems installed per NFPA 20, using suction tanks where NFPA 20 permitted the suction pressure to be not less than 3 psi, is the suction pressure at least 3 psi? (8.1.6.2) <input type="checkbox"/> Yes <input type="checkbox"/> No										

Electric Fire Pump	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Annual Report	2 of 7
---------------------------	-------------------------------------------------------------------------------------------	----------------------	---------------

Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Job #
City		


Fire Pump Test Curves	
Manufacturer's shop test curve	1. 8.3.5.3(1)
Original adjusted fire pump curve using net pump pressures	2. 8.3.5.3(1)
Current adjusted fire pump curve using net pump pressures	3. 8.3.5.3(1)
Original unadjusted fire pump curve using net pump pressures	4. 8.3.5.3(1)
Current unadjusted fire pump curve using net pump pressures	5. 8.3.5.3(1)
Current unadjusted fire pump curve using total pump pressure + supply pressure	6. 8.3.5.7
*Note: The fire pump nameplate data is permitted to be used if the manufacturer's shop test curve is unavailable. (8.3.5.3(2))	

Test Results and Evaluation (8.3.5.7)													
Fire Protection System Demand Information			Fire Pump										
Type of System	Required Pressure at the Pump Discharge Flange (psi)	Required Flow (gpm)	Is the fire pump capable of supply the system demand using the unadjusted pump curve?										
			<input type="checkbox"/> Yes <input type="checkbox"/> No										
			<input type="checkbox"/> Yes <input type="checkbox"/> No										
			<input type="checkbox"/> Yes <input type="checkbox"/> No										
			<input type="checkbox"/> Yes <input type="checkbox"/> No										
			<input type="checkbox"/> Yes <input type="checkbox"/> No										
Are fire pump test results satisfactory?			<input type="checkbox"/> Yes <input type="checkbox"/> No	<table border="0" style="margin-left: auto; margin-right: auto;"> <tr> <td style="padding: 0 10px;">8.1.6</td> <td style="padding: 0 10px;">8.3.5.3</td> <td style="padding: 0 10px;">8.3.5.6</td> </tr> <tr> <td style="padding: 0 10px;">8.3.5</td> <td style="padding: 0 10px;">8.3.5.4</td> <td style="padding: 0 10px;">8.3.5.7</td> </tr> <tr> <td style="padding: 0 10px;">8.3.5.2.1</td> <td style="padding: 0 10px;">8.3.5.5</td> <td></td> </tr> </table>	8.1.6	8.3.5.3	8.3.5.6	8.3.5	8.3.5.4	8.3.5.7	8.3.5.2.1	8.3.5.5	
8.1.6	8.3.5.3	8.3.5.6											
8.3.5	8.3.5.4	8.3.5.7											
8.3.5.2.1	8.3.5.5												

Annual Fire Pump Inspection, Testing, and Maintenance						
Include ALL Monthly and Annual Inspection, Testing, and Maintenance Items						
I = Inspection T = Test M = Maintenance			P = Pass F = Fail N/A = Not Applicable			
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
Fire pump Start/Stop Pressures						
1.01	I	Fire Pump Start Pressure	8.3.2.8(1)(f)		psi	
1.02	I	Fire Pump Stop Pressure	8.3.2.8(1)(f)		psi	
1.03	I	Pressure Maintenance Pump Start Pressure	8.3.2.8(1)(g)		psi	
1.04	I	Pressure Maintenance Pump Stop Pressure	8.3.2.8(1)(g)		psi	
Pump House						
1.05	I	Pump House Heating and Ventilating Louvers. Illumination	8.2.2(1)(a) 8.2.2(1)(b) 8.3.4.3			
Fire Pump System						
1.06	I	Control Valves - Identification Sign	13.3.1			
1.07	I	Control Valves - Inspection	13.3.2			
1.08	I	Pump Suction, Discharge & Bypass Valves Open	8.2.2(2)(a)			
1.09	I	Normally Closed Valves are Closed <i>(Test Header/Venturi Meter)</i>	8.2.2(2)(g) 13.3.2.2			

Electric Fire Pump	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Annual Report	6 of 7
---------------------------	------------------------------------------------------------------------------------------	----------------------	---------------


Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Job #
City		



Curve Identification:
 1. Manufacturer's shop test curve
 2. Original adjusted fire pump curve
 3. Current adjusted fire pump curve

Electric Fire Pump	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Annual Report	7 of 7
---------------------------	------------------------------------------------------------------------------------------	----------------------	---------------

Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Job #
City		



Curve Identification:
 4. Original unadjusted fire pump curve
 5. Current unadjusted fire pump curve
 6. Current unadjusted fire pump curve using total pump pressure + supply pressure

Water Storage Tanks	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Annual Inspection Report	1 of 2
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Address	
City	License #	City	St. Zip
Contact Person	<input type="checkbox"/> SFM	Phone	Job #
Phone	<input type="checkbox"/> CSLB		Misc.

INSPECTION, TESTING, AND MAINTENANCE						
		I = Inspection T = Test M = Maintenance	P = Pass F = Fail N/A = Not Applicable			
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
1.1	I	Water Temperature	9.2.4			
1.2	I	Heating System	9.2.3.1			
1.3	I	Temperature Alarms	9.2.4.2 9.2.4.3			
1.4	I	Condition of Water in Tank	9.2.1			
1.5	I	Water Level	9.2.1			
1.6	I	Air Pressure	9.2.2			
1.7	I	Control Valves	Table 13.1			
1.8	I	Tank - Exterior	9.2.5.1			
1.9	I	Support Structure	9.2.5.1			
1.10	I	Catwalks and Ladders	9.2.5.1			
1.11	I	Surrounding Area	9.2.5.2			
1.12	I	Hoops and Grillage	9.2.5.4			
1.13	I	Painted/Coated Surfaces	9.2.5.5			
1.14	I	Expansion Joints	9.2.5.3			
1.15	I	Interior	9.2.6			
1.16	I	Check Valves	Table 13.1			
2.1	T	Temperature Alarms	9.2.4.2 9.2.4.3			
2.2	T	High Temperature Limit Switch	9.3.4			
2.3	T	Water Level Alarms	9.3.5			
2.4	T	Control Valve - Position	Table 13.1			
2.5	T	Control Valve - Operation	Table 13.1			
2.6	T	Supervisory	Table 13.1			
2.7	T	Level Indicators	9.3.1			
2.8	T	Pressure Gauges	9.3.6			
2.9	T	Automatic Filling Device	9.3.7			

Water Spray Fixed System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Inspection Report	1 of 4
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Address	
City		City	St. Zip
Contact Person	License #	Phone	
Phone	<input type="checkbox"/> SFM	Job #	
	<input type="checkbox"/> CSLB	Misc.	

This building has more than 5 risers. See additional AES 2.9 form attached. Number of AES 2.9 forms attached:

INSPECTION, TESTING, AND MAINTENANCE						
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
Inspection						
1.1	I	Backflow Preventer	Chapter 13			
1.2	I	Check Valves	Chapter 13			
1.3	I	Control Valves (Sealed)	Chapter 13			
1.4	I	Control Valves (Locked, Supervised)	Chapter 13			
1.5	I	Deluge Valve	10.2.2, Chapter 13			
1.6	I	Detection Systems	NFPA 72			
1.7	I	Detector Check Valves	Chapter 13			
1.8	I	Drainage	10.2.8			
1.9	I	Electric Motor	10.2.9 Chapter 8			
1.10	I	Engine Drive	10.2.9 Chapter 8			
1.11	I	Fire Pump	10.2.9 Chapter 8			
1.12	I	Fittings	10.2.4, 10.2.4.1			
1.13	I	Fittings (Rubber Gasketed)	10.2.3.1, Annex			
1.14	I	Gravity Tanks	10.2.10, Chapter 9			
1.15	I	Hangers	10.2.4.2			
1.16	I	Heat (Deluge Valve House)	10.2.1.5 Chapter 13			
1.17	I	Nozzles	10.2.1.1, 10.2.1.2, 10.2.1.6, 10.2.5.1, 10.2.5.2			
1.18	I	Pipe	10.2.1.1, 10.2.1.2, 10.2.4, 10.2.4.1,			
1.19	I	Pressure Tank	10.2.10, Chapter 9			

Water Spray Fixed System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Inspection Report	2 of 4
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Job #	
City			

INSPECTION, TESTING, AND MAINTENANCE						
		I = Inspection	T = Test	M = Maintenance	P = Pass F = Fail N/A = Not Applicable	
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
1.20	I	Steam Driver	10.2.9, Chapter 8			
1.21	I	Strainers	10.2.7			
1.22	I	Suction Tanks	10.2.10, Chapter 9			
1.23	I	Supports	10.2.1.1, 10.2.1.2, 10.2.4.2			
1.24	I	Water Flow Alarm Devices	NFPA 72			
1.25	I	Water Supervisory Alarm Devices	NFPA 72			
1.26	I	Supervisory Signal Devices (Except Valve Supervisory Switches)	NFPA 72			
1.27	I	Water Supply Piping	10.2.6.1 10.2.6.2			
1.28	I	UHSWSS-Detectors	10.4.2			
1.29	I	UHSWSS-Controllers	10.4.3			
1.30	I	UHSWSS-Valves	10.4.4			
		Test				
2.0	T	Backflow Preventer	Chapter 13			
2.1	T	Check Valves	Chapter 13			
2.2	T	Control Valves	13.3.3.1			
2.3	T	Deluge Valve	10.2.2, Chapter 13			
2.4	T	Detection Systems	NFPA 72			
2.5	T	Detector Check Valve	Chapter 13			
2.6	T	Electric Motor	10.2.0, Chapter 13			
2.7	T	Engine Drive	10.2.9, Chapter 8			
2.8	T	Fire Pump	10.2.9, Chapter 8			
2.9	T	Flushing Connection to Riser (Part of Annual Test)	10.2.1.3, Section 10.3			
2.10	T	Gravity Tanks	10.2.10, Chapter 9			
2.11	T	Main Drain Test	13.3.3.4			
2.12	T	Manual Release	10.2.1.3, 10.3.6			

Foam-Water Sprinkler System	California Code of Regulations - Title 19 Inspection, Testing, and Maintenance	Inspection Report	1 of 3
Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Address	
City		City	St. Zip
Contact Person	License #	Phone	
Phone	<input type="checkbox"/> SFM	Job #	
	<input type="checkbox"/> CSLB	Misc.	

This building has more than 5 risers. See additional AES 2.9 form attached. Number of AES 2.9 forms attached:

INSPECTION, TESTING, AND MAINTENANCE						
		I = Inspection T = Test M = Maintenance	<i>P = Pass F = Fail N/A = Not Applicable</i>			
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
Inspection						
1.1	I	Discharge Device Location (Sprinkler)	11.2.5			
1.2	I	Discharge Device Location (Spray Nozzle)	11.2.5			
1.3	I	Discharge Device Position (Sprinkler)	11.2.5			
1.4	I	Discharge Device Position (Spray Nozzle)	11.2.			
1.5	I	Foam Concentrate Strainer(s)	11.2.7.2			
1.6	I	Drainage in System Area	11.2.8			
1.7	I	Proportioning System(s) - All	11.2.9			
Test						
2.1	T	Discharge Device Location	11.3.2.6			
2.2	T	Discharge Device Position	11.3.2.6			
2.3	T	Discharge Device Obstruction	11.3.2.6			
2.4	T	Foam Concentrate Strainer(s)	11.2.7.2			
2.5	T	Proportioning System(s) - All	11.2.9			
2.6	T	Complete Foam-water System(s)	11.3.3			
2.7	T	Foam-water Solution	11.3.5			
2.8	T	Manual Actuation Devices(s)	11.3.4			
2.9	T	Strainer(s) - Mainline	11.2.7.1			
Maintenance						
3.1	M	Foam Concentrate Pump Operation	11.4.6.1 11.4.7.1			
3.2	M	Foam Concentrate Strainer(s)	11.4			
3.3	M	Foam Concentrate Samples	11.2.10			
Proportioning System(s) Standard Pressure Type:						
3.4	M	Ball Drip (automatic type) Drain Valves	11.4.3.1			
3.5	M	Foam Concentrate Tank - Drain and Flush	11.4.3.2			
3.6	M	Corrosion and Hydrostatic Test	11.4.3.3			

