

# **Annual Fire Safety Report**

**September 2011**

**California Polytechnic  
State University  
San Luis Obispo**

**CAL POLY**

# *Fire and Life Safety at Cal Poly*

Cal Poly maintains a comprehensive fire safety program involving response, testing, drills, procedures, and inspection. The campus contracts with the San Luis Obispo City Fire Department for fire suppression response in the Local Response Area of campus. The California Department of Forestry and Fire Protection (Cal Fire) responds to the State Response Area of campus, including the outlying agricultural facilities and surrounding lands. Both agencies participate in mutual aid agreements to ensure complete and timely response to any fires on or near the campus property.

Campus fire safety resources and information can be found at: <http://www.afd.calpoly.edu/ehs/firesafety.asp>

As part of its fire safety and prevention efforts, the University has implemented the following policies in campus housing facilities:

- The policy regarding fire safety in or around the immediate area of the Cal Poly on-campus housing includes the following:
- a. State Fire Code prohibits the use of any open flame including; but not limited to, “Sterno” devices or burning incense.
  - b. Lighting or attempting to light any material on fire in or around on-campus housing is strictly prohibited.
  - c. The use of matches or lighters is prohibited within on-campus housing.
  - d. Candles are prohibited.
  - e. Dangerous chemicals or highly flammable materials including; but not limited to, gasoline, industrial cleaning solvents, spray paint, personal barbecues, charcoal, and/or lighter fluid are not permitted in or around on-campus housing.
  - f. Tampering with fire alarm or fire safety equipment is prohibited including; but not limited to, breaking glass on fire equipment boxes, pulling a fire alarm without cause, misusing fire extinguishers and hoses, and/or tampering with sprinklers, fire/ smoke alarms and exit signs.
  - g. Hallway and stairwell doors are considered fire doors and must be kept closed at all times.
  - h. Posters, flags, drapes, paper lanterns, or other flammable materials cannot be hung from ceilings, doorways, windows, closets, or from furniture. Posters may be hung normally from walls but must be affixed to the wall at all four corners.
  - i. Students may not post anything on the outside of room doors and cannot cover room doors with paper or other materials.
  - j. Holiday lights, rope lights, black lights, halogen lights and fog/ smoke-making machines are not allowed in the residence halls.
  - k. Storage of vehicle parts, fuel and oil is prohibited.
  - l. Hallways must remain clear at all times for safety in case of an evacuation. Residents must not leave personal items in the halls at any time including during hall openings and closings.
  - m. Furniture or other items should never be placed in front of entrances or exits to any room or building.
  - n. Students are required to evacuate buildings for all fire alarms.

## *On Campus Residence Fire Safety Systems*

The following table describes each on-campus residential facility fire safety system.

<b>Building</b>	<b>Sprinkler System?</b>	<b>% Sprinkler</b>	<b>Monitored Fire Alarm?</b>	<b>Smoke Detection</b>	<b>Extinguisher Devices</b>	<b>Placards</b>	<b># Annual Evacuation Drills</b>
016A – Herdsman Hall	None	0%	No	Yes	Yes	No	0
018L – Dairy Science	None	0%	No	Yes	Yes	No	0
048A – Environmental Horticulture	None	0%	No	Yes	Yes	No	0
055A – Beef Cattle Eval. Center	None	0%	No	Yes	Yes	No	0
0560 – Swine Unit	None	0%	No	Yes	Yes	No	0
057C – Veterinary Clinic	None	0%	No	Yes	Yes	No	0
095B – Modular House	None	0%	No	Yes	Yes	No	0

100 - Shasta	None	0%	No	Yes	Yes	Yes	2
101 – Diablo	None	0%	No	Yes	Yes	Yes	2
102 - Palomar	None	0%	No	Yes	Yes	Yes	2
103 – Whitney	None	0%	No	Yes	Yes	Yes	2
104 – Lassen	None	0%	No	Yes	Yes	Yes	2
105 – Trinity	None	0%	Yes	Yes	Yes	Yes	2
106 – Santa Lucia	None	0%	Yes	Yes	Yes	Yes	2
107 – Muir	None	0%	Yes	Yes	Yes	Yes	2
108 – Sequoia	None	0%	Yes	Yes	Yes	Yes	2
109 – Fremont	None	0%	Yes	Yes	Yes	Yes	2
110 – Tenaya	None	0%	Yes	Yes	Yes	Yes	2
113A– Sierra Madre 0	None	0%	Yes	Yes	Yes	Yes	2
113B – Sierra Madre 1	None	0%	Yes	Yes	Yes	Yes	2
113C – Sierra Madre 2	None	0%	Yes	Yes	Yes	Yes	2
113D – Sierra Madre 3	None	0%	Yes	Yes	Yes	Yes	2
113E – Sierra Madre 4	None	0%	Yes	Yes	Yes	Yes	2
113F – Sierra Madre 5	None	0%	Yes	Yes	Yes	Yes	2
114A – Yosemite 0	None	0%	Yes	Yes	Yes	Yes	2
114B – Yosemite 1	None	0%	Yes	Yes	Yes	Yes	2
114C – Yosemite 2	None	0%	Yes	Yes	Yes	Yes	2
114D – Yosemite 3	None	0%	Yes	Yes	Yes	Yes	2
114E – Yosemite 4	None	0%	Yes	Yes	Yes	Yes	2
114F – Yosemite 5	None	0%	Yes	Yes	Yes	Yes	2
114G – Yosemite 6	None	0%	Yes	Yes	Yes	Yes	2
114H – Yosemite 7	None	0%	Yes	Yes	Yes	Yes	2
114J – Yosemite 8	None	0%	Yes	Yes	Yes	Yes	2
114K – Yosemite 9	None	0%	Yes	Yes	Yes	Yes	2
121A – McCloud	None	0%	No	Yes	Yes	No	0
121B – Santa Ynez	None	0%	No	Yes	Yes	No	0
123B – Peterson Ranch	None	0%	No	Yes	Yes	No	0
127G – Escuela Beef Center	None	0%	No	Yes	Yes	No	0
150I – Poultry Science	None	0%	No	Yes	Yes		0
170A – Cerro Morro	Full	100%	Yes	Yes	Yes	Yes	2
170B – Cerro Cabrillo	Full	100%	Yes	Yes	Yes	Yes	2
170C – Cerro Hollister	Full	100%	Yes	Yes	Yes	Yes	2
170D – Cerro Romauldo	Full	100%	Yes	Yes	Yes	Yes	2
170E – Cerro Bishop	Full	100%	Yes	Yes	Yes	Yes	2
170F – Cerro Islay	Full	100%	Yes	Yes	Yes	Yes	2
170G – Cerro San Luis	Full	100%	Yes	Yes	Yes	Yes	2
171A – Aliso	Full	100%	Yes	Yes	Yes	Yes	2
171B – Buena Vista	Full	100%	Yes	Yes	Yes	Yes	2
171C – Corralitos	Full	100%	Yes	Yes	Yes	Yes	2
171D – Dover	Full	100%	Yes	Yes	Yes	Yes	2
171E – Estrella	Full	100%	Yes	Yes	Yes	Yes	2
171F – Foxen	Full	100%	Yes	Yes	Yes	Yes	2
171G – Gypsum	Full	100%	Yes	Yes	Yes	Yes	2
171H – Huasna	Full	100%	Yes	Yes	Yes	Yes	2
171I – Inyo	Full	100%	Yes	Yes	Yes	Yes	2

## *Fire Safety Statistics*

The following table contains information regarding fires in on-campus student housing facilities during the reporting period:

<b>Location</b>	<b># of Fires</b>	<b>Cause of Fire</b>	<b>Fire Related Injuries</b>	<b>Fire Related Deaths</b>	<b>Value of Damage</b>
Cerro Vista (101301)	1	Cooking	0	0	\$100-\$999
Poly Canyon Village (101167) (101208)	2	Cooking / Cooking	0	0	\$0/ \$100-\$999

## *Fire Safety Procedures*

All fires in campus facilities must be reported immediately to the University Police via 911.

Campus building evacuation procedures can be found here:

[http://www.afd.calpoly.edu/ehs/docs/Campus\\_Building\\_Evacuation\\_Procedure.pdf](http://www.afd.calpoly.edu/ehs/docs/Campus_Building_Evacuation_Procedure.pdf)

The current Campus Safety Report (Clery Report) can be found here:

<http://www.afd.calpoly.edu/police/services/docs/CleryReport.pdf>