



CONNECT TO SPRINKLER SYSTEM PER CAL POLY STANDARD DETAIL 659G,
INSTALL BACKFLOW PREVENTER WITH FDC PER CAL POLY STD DETAIL 6420 AND FP-0.0
CONTRACTOR TO CORE THROUGH BOTTOM OF UTILIDOR FOR BOTH LINES AND BACKFILL UNDERNEATH UTILIDOR PER CAL POLY STANDARDS

All materials shall be listed for fire water line use by an approved Office of the State Fire Marshal testing laboratory (i.e. FM or UL) and shall be submitted with shop drawings stamped by a registered design professional from the State of California to the AHJ for review and approval prior to procurement and construction.

STANDARD CURRENT AS OF: 01/01/2025

APPROVED BY: FMD

NOTES:



CAL POLY

UTILIDOR TIE-IN - DOMESTIC/FIRE WATER

6335