



Notes:

1. No bottom or side conduit connections are allowed.
2. Only service box, PXCM and TXIO components allowed in PXCM enclosure.
3. Component Panel is for transformers, power supplies and relays.
4. Gutters will have screw covers. No hinged covers allowed.
5. Any panel layout not shown must be approved by Cal Poly Representative, FMD, and the Campus Engineer.
6. PXCM and TXIO layout will be for smoke control as shown in PXCM manual. No other layout allowed without approval from Cal Poly Representative, FMD, and the Campus Engineer.

STANDARD CURRENT AS OF: 01/01/2025

APPROVED BY: FMD

NOTES:



CAL POLY

PROGRAMMABLE CONTROLLER-MODULAR  
(PXCM) LAYOUT

M1