

BUILDING DATA

Calif. Polytechnic State University Building 80, Environmental Health and Safety.

Original Construction 1951.

Occupancy Type: B Occ., with A-3 Accessory (less than 10%) (Per CBC Sec. 303.5) and Type S-1 Occ., non-sprinklered

Construction Type: V-B

Any Materials allowed by code –Metal Building w/ Wood framing

Fire separation distance is greater than 30', NO LIMIT on exterior openings per table 705.8

Occupancy Separations: Mixed Occupancy w/ no separations

No. of Stories: 1 – OK per Table 503, 2 stories Allowed

(E) Building Height- 25' abv. avg. grd. plane, 40' allowed

Actual Building Area-

B Occ. -	2725 sq. ft
S-1 Occ.-	3677 sq. ft.
Total-	6402 sq. ft.

Allowable Areas-
9000 SF/ 9000SF

Allowable Area Calculation

$$\frac{.30\% + .41\%}{1.00\%} = \frac{.71}{1.00} \text{ OK}$$

At = 9,000 sq. ft. (Per Table 503)

6,402 SF < 9,000 SF **OK**

DSA Info-

DSA number 01-114729.

Exterior Path of Travel, offices, restrooms.

Fire Sprinkler Info-

No Sprinklers

SFM FILE #- 18-40-03-0001-143